



EPD34 Electromagnetic Flow Meter Operation Manual



FineTek Co., Ltd.

No.16, Tzuchiang St., Tucheng Industrial Park, New Taipei City 23678

Tel: 886-2-22696789

Fax: 886-2-22686682

Website: <http://www.fine-tek.com>

E-mail: info@fine-tek.com

Contents

1. Reading Labels	1
2. Product Warranty.....	2
2.1 New Product Warranty	2
2.2 Repair Warranty	2
2.3 Service Network.....	3
3. Product Inspection	4
3.1 Check Content	4
3.2 Safety Inspection	4
4. Summary	4
5. Product Features	5
6. Applicable Scope.....	5
7. Environmental Condition	5
8. Working Principles	6
9. Technical Performance	7
9.1 Basic Parameters and Performance Indicators.....	7
9.1.1 Technical Specification Table	7
9.1.2 Accuracy class & tolerance	8
9.1.3 Recommended Flow Range for Tube Diameters	8
9.1.4 Pressure resistance and inner diameter specification for various tube diameters	9
9.1.5 Lining Material.....	9
9.1.6 Electrode Material	10
9.1.7 Housing Protection Rating(IP).....	10
9.2 Execution Standards.....	10
10. Appearance and Dimension.....	11
10.1 JIS 7.5K & 10K & 20 K.....	11
10.2 ANSI 150Lbs & 300Lbs.....	13
10.3 DIN PN40 & PN16 & PN10	14
11. Installation.....	15
11.1 Conditions required to guarantee the measurement accuracy of the electromagnetic flow meter:	15
11.2 Safety Measures	15
11.3 Inspection before Installation	15
11.4 Handling.....	16
11.5 Correct Installation	16
11.6 Notes for Installation on the Pipe	18
11.7 Grounding Requirements	19

12. Wiring and Using	20
12.1 Wiring.....	20
12.1.1 Notes for Wiring	20
12.1.2 Diagram of Sensor Wiring Terminal	20
12.1.3 Diagram of Transmitter Wiring Terminal	21
12.1.4 Signal Electrical Cable Wiring	23
12.2 Input / Output Function Wiring	24
12.2.1 4-20mA Current output	24
12.2.2 Pulse Output	24
12.2.3 RS-485 Communication	24
12.2.4 Digital output 1 (DO1)	25
12.2.5 Digital output 1 (DO2)	25
12.2.6 Digital input (DI)	26
12.2.7 Analogy input (AI)	26
13. Inspection before Power-On	26
14. Parameter Functions	27
14.1 Procedure for Menu Setting	27
14.1.1 Functions of the Display Interface	27
14.1.2 Button Functions in Parameter Setting Status:	27
14.2 Various Parameter Setting Ranges.....	28
14.3 System record illustration.....	32
15. Ordering Information	34
16. Transportation and Storage.....	36
17. Fault Inspection and Repair	37
18. MODBUS Communication Protocol	40

1. Reading Labels

Thanks for purchasing FineTek's Product. This operation manual describes the product features, working principles, operation and maintenance methods. It makes the user fully understand how to use the product correctly, so as to prevent dangerous situations such as device damage or operator injury.

- Please read this operation manual completely and carefully before using the product.
- Please contact the company if this operation manual can't satisfy your demands.
- The content of the operation manual is updated based on the version upgrade, which will be uploaded to the website for the user to access.
- Please don't disassemble or repair the product on your own, as this will make you disqualified from availing of the warranty service. Please send the product back to the company for repair and calibration, or just contact the company.
- Explanation of warning signs:



Danger→ It indicates that wrong operation will cause death or major disasters.



Note→ It indicates that wrong operation will cause injury and device damage to some extent.



Electric shock→ It warns of possible electric shock.



Fire→ It warns of possible fire.



Prohibited→ It indicates the prohibited wrong behavior.

2. Product Warranty

2.1 New Product Warranty

- We don't charge for the inspection, part/s and repair for the product of the company that has a defect within 12 months from the delivery date and meets the warranty terms.
- If the product defect is not due to human error during its transportation, user may change to a new unit from the company within 7 days from delivery date.
- When the product needs to be sent back to the factory for repair, please send the whole set, and don't disassemble the parts. Moreover, please be sure it is completely packed to avoid damage and causing more loss and defect during the transportation.
- The warranty is not available for causes that fall under the following circumstances, for which the company shall charge for the inspection, part/s and repair according to the actual condition:
 - The product or its parts are beyond the warranty period.
 - Fault or damage is caused by not following the instruction and use environment described on the operation manual.
 - The product damage is caused by a force majeure factor (natural disasters, floods, fire, earthquakes, lightning, typhoon, etc.), human destruction (scratches, dropping, latch broken, tapping, cracks and punching), human error (using improper voltage, high-humidity, water leakage, stain, corrosion, loss, improper storage, etc.) and other abnormal factors.
 - The damage is caused by the customer or the 3rd party through the installation, addition, expansion, modification and repair of parts not authorized or certified by the company.
 - The volume label information is wrong or unclear, so the product serial number can't be confirmed.

2.2 Repair Warranty

A **6-month** warranty service is provided for the repaired part of the product, during which the same product can be repaired free of charge in case of the same fault.

2.3 Service Network

Company	Address	Telephon	Fax
Taipei Headquarters (Taiwan)	No.16, Tzuchiang St., Tucheng Industrial Park, New Taipei City 23678	+886 2-2269-6789	+886 2-2268-6682
Taichung Sales office (Taiwan)		+886 4-2337-0825	+886 4-2337-0836
Kaohsiung Sales office (Taiwan)		+886 7-333-6968	+886 7-536-8758
Fine automation Co., Ltd. (China)	No. 451, Duhui Road, Zhuanqiao Township, Minhang District, Shanghai City 201109	+86 021-64907260	+86 021-6490-7276
Aplus FineTek Sensor Inc. (America)	355 S. Lemon Ave, Suite D, Walnut, CA 91789	1 909 598 2488	1 909 598 3188
FineTek Pte Ltd. (Singapore Branch)	37 Kaki Bukit Place, Level 4 Singapore 416215	+65 6452-6340	+65 6734-1878
FineTek GmbH (Germany Branch)	Bei den Kämpen 26 21220 Seevetal-Ramelsloh, Germany	+49 (0) 4185 8083 0	+49 (0) 4185 8083 80
FineTek Co., Ltd. (Indonesia Branch)	PERGUDANGAN TUNAS BITUNG JL. Raya Serang KM. 13,8, Blok C3 No. 12&15, Bitung Cikupa, Tangerang 15710	+62 021-2958-1688	

3. Product Inspection

3.1 Check Content

- 1 flow meter
- 1 operation manual
- 1 product inspection sheet
- 1 grounding ring set (2 rings)(Optional)

3.2 Safety Inspection

- Please check whether the external package is deformed or damaged. Please remember to take a picture for evidence for compensation later.
- After unpacking, please check whether the content is deformed or damaged, or has any quality problem. Please remember to take a picture for evidence for compensation later.
- After unpacking, please check whether the content is consistent with the ordering info, and whether the quantity is right.
- Please contact the company within 7 days if any of the above situations occur (attach the picture together with your complaint). Otherwise, we won't compensate for, change or repair the product defect.

4. Summary

The company's electromagnetic flow meter adopts coil excitation, which is more stable than the traditional magnetism generation. After strict vibration and anti-noise test, it can work stably and is highly tolerant of complex environments in the industrial field, which also has a longer life span in practical application.

The electromagnetic flow meter has kept on evolving since its initial development, which is widely applied in monitoring various industrial fluid pipes, including power generation, water treatment, food, medication, shipping, dyeing & finishing, and semi-conductor process industries. With its simple working principle, the electromagnetic flow meter is widely applicable in various environments as long as the correct model is selected to match the fluid properties.

5. Product Features

- The measurement results is not affected by the change of liquid density, viscosity, temperature, pressure and conductivity.
- There are only two measurement points in the measuring tube without baffle and movable parts, so it won't cause pressure loss and jam.
- It can test the flow for the conducting fluid and the fluidic containing some solid granules.
- The straight tube section required for the installation just needs the upstream front 5D and downstream 2D of the flow meter without complicated pipeline design.
- The measurement turndown ratio can reach 1:100, which can achieve high accuracy especially for measuring small flow.
- It has a self-diagnosis function, which can automatically detect the excited signal, whether the measuring tube is empty and whether the electrode is stained or damaged.
- The lining can be common NBR(Nitrile), high-temperature or acid-proof & alkali-proof PTFE(Teflon)
- The maximum fluidic temperature permitted can reach 120°C(Teflon)
- The flow converter setting is simple, with powerful functionality.
- Available for records for parameter modifications, boot/ shut down device (Option)
- Authority management is available in Menu (Option)

6. Applicable Scope

- Conductivity: > 5μS/cm
- Fluid properties: Pure liquid and fluidic containing some solid granules.
- Application industries: Power generation, water treatment, food, medication, shipping, dying & finishing, and semi-conductor process


7. Environmental Condition

- Ambient environment : -40°C ~ 70°C
- Relative humidity: 5% ~ 95% of RH, without condensing water
- Atmospheric pressure: 86 ~ 106 Kpa
- Power supply: 100~240Vac 50/60Hz or DC24V

8. Working Principles

The working principle of the electromagnetic unit is based on the Faraday law of electromagnetic induction. When the conductor moves in the magnetic field, it will generate induced EMF on both sides of the conductor in the orthogonal direction of the magnetic field direction and the motion direction. The EMF is directly proportional to the motion speed of the conductor and the magnetic induction intensity.

As shown in <Figure 1>, the conducting fluidic passes through the insulating tube with the internal diameter of $D(m)$ at the average flowing speed $V(m/s)$ that is equipped with a pair of measuring electrodes. Moreover, the tube is in a magnetic field with uniform magnetic induction intensity of $B(T)$. In this case, the electrodes will induce the EMF E at the orthogonal direction of the magnetic field and the flowing direction. According to the law of electromagnetic induction, E can be written as Equation (1):



<Figure 1>

$$E = kB \cdot D \cdot V \quad (V) \quad \dots\dots\dots (1)$$

Wherein, k is the proportional coefficient.

The volume flow can be written as

$$q_v = \frac{\pi D^2}{4} V \quad (m^3/s) \quad \dots\dots\dots (2)$$

From Equation (1) and (2), we can get:

$$q_v = \frac{\pi D}{4k} \frac{E}{B} (m^3/s) \quad \dots\dots\dots (3)$$

Thus, EMF can be represented as:

$$E = \frac{4kB}{\pi D} q_v (V) \quad \dots\dots\dots (4)$$

When B is a constant in Equation(3)

$$\frac{\pi D}{4k} \frac{1}{B} = A, \quad \text{Equation(3) can be modified as:}$$

$$q_v = AE (m^3/s) \quad \dots\dots\dots (5)$$

It can be concluded that the flow q_v is directly proportional to the EMF E .

9. Technical Performance

9.1 Basic Parameters and Performance Indicators

9.1.1 Technical Specification Table


Item	EPD34
Display	LCM 128* 64 pixel backlit type
Buttons	Tri-button operation
Communication interface	RS-485 (Modbus)
Accuracy	±0.5% of reading@1m/s(0.2% optional)
Operation temperature of lining	NBR : Temperature resistance<80℃, mainly applied in low-concentrated acid and alkane liquid. With excellent anti-abrasion property, it can be used to measure liquid with impurities. It is applicable to coal slurry, mud and industrial sewage. Neoprene : Temperature resistance <80℃, resistant to general low-concentrated acid and alkane. It is applicable to industrial sewage and tap water. PTFE: Temperature resistance <120℃. With stable chemical properties, it is mainly applied in strong corrosive medium such as concentrated acid and alkane or an environment with requirements for cleanliness. It is applicable to various liquids and chemical agents in food processing.
Ambien temperature	-40~70℃*
Fluidic conductivity	>5uS/cm ³
Measuring scope	0.1m/s~10m/s
Current output accuracy	0.1% of Pulse Output Accuracy Temperature coefficient (100ppm/℃)* *
Operating pressure	16 kg/cm ² (Please contact FineTek if pressure requested more than 16 Kg/cm ²)
Current output mode	Proactive
Analog output	4~20mA
Maximum load of current output	<700Ω
Alarming current	3.6mA or 22mA
Frequency output scope	2~8KHz
Pulse width	Automatic (pulse width 50%)
Pulse mode	Isolated NPN Transistor output 32vdc/200mA
Time constant	1~100s
Control output (DO)	Isolated NPN Transistor output 32vdc/200mA; 2-CH
Control input (DI)	Dry contact ON< 200Ω ; 1,000Ω< OFF ; 1-CH
Data logger(Optional)	500 items. With calendar (Internal battery: Lift time>6 month)
Baud rate	1200~57600bps
Protection rating	IP68(Transducer), IP67/NEMA 4X(Transmitter)
Enclosure material	Aluminum alloy
Input power	AC100~240Vac or DC24V
Power consumption	<10 W
Wire inlet specification	1/2"NPT*2(Transducer),M20X1.5*4(Transmitter)
signal power cable	< 100m***
Excitation mode	Pulse DC
Vibration regulation	MIL-STD-202G-201A:2002
EMC regulation	IEC/EN 61326-1 Class A table 2

* It can't display when LCM is lower than -20℃

** Combined with FineTek sensor

***When the signal power cable is longer than 50m, the empty tube detection is unavailable.

9.1.2 Accuracy class & tolerance



9.1.3 Recommended Flow Range for Tube Diameters

Pipe diameter (mm)	Flow range (m ³ / h)	
	Flowing speed 0.1~1.0m/s	Flowing speed 1.0~10m/s
15	0.06~0.64	0.64~6.4
25	0.17~1.77	1.77~17.7
40	0.45~4.5	4.5~45.2
50	0.71~7.1	7.1~71
65	1.19~11.9	11.9~119
80	1.81~18.1	18.1~181
100	2.83~28.3	28.3~283
125	4.42~44.2	44.2~442
150	6.36~63.6	63.6~636
200	11.3~113	113~1130
250	17.7~177	177~1770
300	25.4~254	254~2540
350	34.6~346	346~3460
400	45.2~452	452~4520
450	57.2~572	572~5720
500	70.7~707	707~7070

9.1.4 Pressure resistance and inner diameter specification for various tube diameters

Nominal diameter		Specification of measurement tube	Inner diameter of measurement tube			
			NBR		PTFE	
mm	Inch	JIS	mm	Inch	mm	Inch
25	1	20K	-	-	-	-
32	1-1/4	20K	-	-	-	-
40	1-1/2	20K	-	-	38	1.50
50	2	10K	-	-	49	1.93
65	2-1/2	10K	-	-	64	2.52
80	3	10K	-	-	77	3.03
100	4	10K	-	-	102	4.02
125	5	10K	-	-	128	5.04
150	6	10K	-	-	151	5.94
200	8	10K	-	-	207	8.15
250	10	10K	-	-	256	10.08
300	12	10K	-	-	301	11.85
350	14	10K	-	-	-	-
400	16	10K	-	-	-	-
450	18	10K	-	-	-	-
500	20	10K	-	-	-	-

9.1.5 Lining Material

Lining material	Main properties	Application scope
PTFE	1. Stable chemical properties, resistance to various acid, alkane, and salt solutions and various organic solvents. It is not tolerant to the corrosion of ClF_3, high-temperature OF_3 and high-speed liquid oxygen and ozone. 2. The anti-abrasion property is average.	1. $-20\sim 120^\circ\text{C}$ 2. Strong corrosive medium such as concentrated acid and alkane.
NBR	1. Excellent flexibility, highly tearing force capability, good wear resistance 2. It is resistant to low concentrations of acid, alkali, salt solution; It is not tolerant the corrosion of oxidizing mediums.	1. $< 80^\circ\text{C}$ 2. Neutral-strong wearing mineral pulp, coal slurry and mud slurry
Neoprene	1. Neutral wearing capability 2. It is resistant to low concentrations of acid, alkali, acid corrosion.	1. $< 80^\circ\text{C}$ 2. Water, Industrial water , Seawater

9.1.6 Electrode Material

Electrode material	Anti-corrosion property
Stainless steel (316L)	It is applied in water, sewage and organic corrosive medium.
Hastelloy alloy	It is resistant to the corrosion of the medium mixture of oxidizing acid such as Nitric acid, mixed acid or Sulfuric acid. Moreover, it is resistant to the corrosion of the oxidizing salt such as Fe^{2+} 、 Cu^{2+} or other substances containing oxidants such as the salt solution of hypochlorous acid above the ambient temperature and sea water.
Titanium	It is resistant to the corrosion of sea water, various oxides, salt solution of hypochlorous acid, oxidating acid (including fuming Nitric acid) and organic acid and alkane. It is not resistant to the corrosion of pure reducing acid (such as Sulfuric acid and Hydrochloric acid). However, the anti-corrosion property will be greatly degraded if the acid contains some oxidants.
Tantalum	It has excellent corrosion resistance. Its characteristic is similar to glass. In addition to hydrofluoric acid , nitric acid , alkali, it could resist almost all chemical medium (including boiling hydrochloric acid, nitric acid and sulfuric acid below 175°C). It could not resist corrosion in alkali.

9.1.7 Housing Protection Rating(IP)


Transducer: IP68

Transmitter: IP67/NEMA 4X

9.2 Execution Standards

IEC 60068-2-3	EN 61326-1:2013
IEC 61326-1	EN 55011:2009/A:2010
IEC 60092-504	ISO 4064-1
JIS B2220	JIS B7554-1997
ANSI B16.5	DIN 25 Series

10. Appearance and Dimension



10.1 JIS 7.5K & 10K & 20 K


Connection specification		JIS 10K															
Nominal diameter(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
Lining material		PTFE															
Length	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
External diameter	ϕD	95	125	140	155	175	185	210	250	280	330	400	445	490	560	620	675
PCD	ϕC	70	90	105	120	140	150	175	210	240	290	355	400	445	510	565	620
Flange thickness	t	12	14	16	16	18	18	18	20	22	22	24	24	26	28	30	30
Inclined angle of screw hole	θ°	45	45	45	45	45	22.5	22.5	22.5	22.5	15	15	11.25	11.25	11.25	9	9
Diameter of screw hole	θh	15	19	19	19	19	19	19	23	23	23	25	25	25	27	27	27
Quantity of screw holes	N	4	4	4	4	4	8	8	8	8	12	12	16	16	16	20	20
Height of sensor casing	H1	75	88	125	125	145	145	195	195	270	305	365	406	470	530	580	630
Total height*1	H2	229	250	276	284	304	309	346	366	429	468	534	578	637	699	752	802
Weight (kg)*2	-	3.4	5.3	5.3	6.1	7.4	8.3	11.4	16	22	31.7	52.5	68	86.8	107.7	--	--

Connection specification		JIS 20K											
Nominal diameter(mm)		15	25	40	50	65	80	100	125	150	200	250	300
Lining material		PTFE											
Length	L	200	200	200	200	200	200	250	250	300	350	400	500
External diameter	ϕD	95	125	140	155	175	200	225	270	305	350	430	480
PCD	ϕC	70	90	105	120	140	160	185	225	260	305	380	430
Flange thickness	t	14	16	18	18	20	22	24	26	28	30	34	36
Inclined angle of screw hole	θ°	45	45	45	22.5	22.5	22.5	22.5	22.5	15	15	15	11.25
Diameter of screw hole	θh	15	19	19	19	23	23	23	25	25	25	27	27
Quantity of screw holes	N	4	4	4	8	8	8	8	8	12	12	12	16
Height of sensor casing	H1	75	88	125	125	145	145	195	195	270	305	365	406
Total height*1	H2	229	250	276	284	304	316	354	376	440	476	547	594
Weight (kg)*2	-	3.8	5.5	5.5	6.2	7.4	10.7	14.9	22	29.5	41.8	72.7	92.6

Remarks:

*1: For DN40~DN80, the lining protective ring is 2mm, so the total length of the flow meter shall be increased by L+4mm. For DN100~DN300, the lining protective ring is 0.5mm, so the total length of the flow meter shall be increased by L+1mm; total length (L) tolerance is ± 3 mm, total height (H2) tolerance is ± 5 mm

*2: To shows the weight of transducer only. Not include the weight of transmitter 2.06kg




Connection specification		JIS 7.5K										
Nominal diameter(mm)		50	80(75)	100	150	200	250	300	350	400	450	500
Lining material		PTFE										
Length	L	200	200	250	300	350	400	500	500	600	600	600
External diameter	ϕD	185	211	238	290	342	410	464	530	582	652	706
PCD	ϕC	143	168	195	247	299	360	414	472	524	585	639
Flange thickness	t	16	18	18	20	21	23	26	26	26	28	28
Inclined angle of screw hole	θ°	45	45	45	30	22.5	22.5	18	18	15	15	15
Diameter of screw hole	θh	19	19	19	19	19	23	23	24	24	28	28
Quantity of screw holes	N	4	4	4	6	8	8	10	10	12	12	12
Height of sensor casing	H1	125	145	195	270	305	365	406	470	530	580	630
Total height*1	H2	299	322	360	433	473	538	587	655	709	767	817
Weight (kg)*2	-	7.7	10.9	14.3	24.1	35.3	54.1	73.4	--	--	--	--

Remarks:

*1: For DN40~DN80, the lining protective ring is 2mm, so the total length of the flow meter shall be increased by L+4mm. For DN100~DN300, the lining protective ring is 0.5mm, so the total length of the flow meter shall be increased by L+1mm; total length (L) tolerance is ±3mm, total height (H2) tolerance is ±5mm

*2: To shows the weight of transducer only. Not include the weight of transmitter 2.06kg



10.2 ANSI 150Lbs & 300Lbs


Connection specification		ANSI 150Lbs															
Nominal diameter(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
Lining material		PTFE															
Length	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
External diameter	ϕD	89	108	127	152	178	190	229	254	279	343	406	483	533	597	635	699
PCD	ϕC	60	79	98	121	140	152	191	216	241	298	362	432	476	540	578	635
Flange thickness	t	10	13	16	17	21	22	22	22	24	27	29	30	33	35	38	41
Inclined angle of screw hole	θ°	45	45	45	45	45	45	22.5	22.5	22.5	22.5	15	15	15	11.25	11.25	9
Diameter of	θh	16	16	16	19	19	19	19	22	22	22	25	25	29	29	32	32
Quantity of screw	N	4	4	4	4	4	4	8	8	8	8	12	12	12	16	16	20
Height of sensor	H1	76	89	125	125	145	145	195	195	265	305	365	406	470	530	580	630
Total height*1	H2	227	242	270	282	305	311	356	368	426	473	537	595	657	716	759	851
Weight (kg)*2	-	4.6	6.1	4.9	6.8	9.2	10.7	16.3	19.4	25.5	42.6	65.7	98	123.2	151.3	--	--

Connection specification		ANSI 300Lbs															
Nominal diameter(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
Lining material		PTFE															
Length	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
External diameter	ϕD	98	124	156	165	190	210	254	279	318	381	445	521	584	648	711	775
PCD	ϕC	67	89	114	127	149	168	200	235	270	330	387	451	514	572	629	686
Flange thickness	t	13	16	19	21	24	27	30	33	35	40	46	49	52	56	59	62
Inclined angle of screw hole	θ°	45	45	45	22.5	22.5	22.5	22.5	22.5	15	15	11.25	11.25	9	9	7.5	7.5
Diameter of screw	θh	16	19	22	19	22	22	22	22	22	25	29	32	32	35	35	35
Quantity of screw	N	4	4	4	8	8	8	8	8	12	12	16	16	20	20	24	24
Height of sensor	H1	76	89	125	125	145	145	195	195	265	305	365	406	470	530	580	630
Total height*1	H2	231	250	284	289	311	321	368	381	443	490	553	612	680	740	794	886
Weight (kg) *2	-	5.1	7.3	9.1	10.3	12.8	16.5	26.6	33	42.3	67.6	98.9	145	--	--	--	--

Remarks:

*1: For DN40~DN80, the lining protective ring is 2mm, so the total length of the flow meter shall be increased by L+4mm. For DN100~DN300, the lining protective ring is 0.5mm, so the total length of the flow meter shall be increased by L+1mm; total length (L) tolerance is ±3mm, total height (H2) tolerance is ±5mm


*2: To shows the weight of transducer only. Not include the weight of transmitter 2.06kg



10.3 DIN PN40 & PN16 & PN10

Connection specification		DIN PN40						DIN PN16					
Nominal diameter(mm)		15	25	40	50	65	80	65	80	100	125	150	200
Lining material		PTFE											
Length	L	200	200	200	200	200	200	200	200	250	250	300	350
External	φD	95	115	150	165	185	200	185	200	220	250	285	340
PCD	φC	65	85	110	125	145	160	145	160	180	210	240	295
Flange thickness	t	18	18	18	20	22	24	18	20	20	22	22	24
Inclined angle of screw hole	θ°	45	45	45	45	22.5	22.5	45	22.5	22.5	22.5	22.5	15
Diameter of	θh	14	14	18	18	18	18	18	18	18	18	22	22
Quantity of	N	4	4	4	4	8	8	4	8	8	8	8	12
Height of sensor	H1	76	89	125	125	145	145	145	145	195	195	265	305
Total height*1	H2	230	246	281	289	309	316	309	316	351	366	435	476
Weight (kg)*2	-	5.2	7.1	5.5	6.2	7.4	10.7	7	10.1	14.1	19.4	26.7	38.4

Connection specification		DIN PN10						
Nominal diameter(mm)		200	250	300	350	400	450	500
Lining material		PTFE						
Length	L	350	400	500	350	600	600	600
External	φD	340	395	445	490	565	615	670
PCD	φC	295	350	400	460	515	565	620
Flange thickness	t	24	26	26	28	32	38	38
Inclined angle of screw hole	θ°	22.5	15	15	11.25	11.25	9	9
Diameter of	θh	22	22	22	22	26	26	26
Quantity of	N	8	12	12	16	16	20	20
Height of sensor	H1	305	365	406	470	530	580	630
Total height*1	H2	476	534	603	637	701	750	800
Weight (kg)*2	-	31.7	52.5	68	86.8	107.7	--	--



Remarks:

*1: For DN40~DN80, the lining protective ring is 2mm, so the total length of the flow meter shall be increased by L+4mm. For DN100~DN300, the lining protective ring is 0.5mm, so the total length of the flow meter shall be increased by L+1mm; total length (L) tolerance is ±3mm, total height (H2) tolerance is ±5mm

*2: To shows the weight of transducer only. Not include the weight of transmitter 2.06kg

11. Installation

The design, test and power supply for the flow meter are based on the related regulations. User must strictly follow the instructions to guarantee the safe operation and normal working of the flow meter.

11.1 Conditions required to guarantee the measurement accuracy of the electromagnetic flow meter:

- The test liquid is conducting.
- The measuring pipe must be filled with liquid.
- The test liquid must be uniform, so as to prevent the non-uniform conductivity (which will result in serious interference). If you need to add some chemicals dynamically, it should be added in the downstream of the flow meter.
- The electromagnetic flow meter must be well grounded. Especially in the plastic pipe, the grounding ring must be installed in order to perform solid grounding.
- The straight tube section is required to be at least 5D at the flow meter inlet (internal diameter of the measuring pipe), and at least 2D at the flow meter outlet.
- The flow meter should be kept away from strong EMI, and it should not be installed near the large motors or transformers.

11.2 Safety Measures

To guarantee human and device safety, the instructions below must be followed:


- Before selecting the location and installing the flow meter, the user should carefully read the related parts in this manual, and consider the safety requirements for the flow meter, related devices and machine body environment.
- The flow meter installation and repair must be performed by the personnel with some flow meter knowledge.
- The flow meter sensors and pipes must be correctly installed, and the sealing must be safe and reliable. The liquid pressure should not exceed the maximum working pressure described on the flow meter specification.
- Proper measures must be taken to prevent electrical shock accident.
- The handling equipment of the flow meter should meet the safety requirements.

11.3 Inspection before Installation

- Check whether the flange, lining, casing and outgoing line sleeve are damaged.
- Open the box cover to check whether the wiring printed circuit is loosened or damaged.
- Check whether the model number on the nameplate is consistent with the order information.

11.4 Handling


The flow meter must be handled with the correct handling method. The safety load and protection action of the handling equipment should meet the related regulations. The transmitter box (for integrated flow meter) or enclosure (for separated flow meter) must not be tied up to handle the flow meter.




11.5 Correct Installation

It is very important to select the installation site and install the flow meter correctly. If any mistake is made during the installation, it will affect the measuring accuracy or the life span of the flow meter, or even cause damage. When selecting the installation site, please pay special attention to the following:

- The axis of the measuring electrode must be approximate to the horizontal direction (Generally, the angle from the level line is within 10° .)




- The measuring pipe must be filled with liquid.
- The flow meter must be equipped with the straight tube section in the length of at least $5 \times D$ at the front side (D is the internal diameter of the flow meter), and the straight tube section in the length of at least $2 \times D$ at the rear side (D is the internal diameter of the flow meter).



- The flowing direction of the fluidic is the same as the arrow direction on the flow meter.
- Please prevent the vacuum in the pipe, which will damage the lining of the flow meter.
- The flow meter must be free from strong electromagnetic field. The magnetic intensity of the flow meter installation site must be smaller than 400A/m . (It should not be installed near large motors or transformers).

- There should be enough space left surrounding the flow meter for installation and repair.
- g. Unknown the measuring pipe vibrates, a support frame should be set up on both sides of the flow meter.
 - h. When measuring the mixture of different media, the distance between the mixing point and the flow meter must be $30 \times D$ at least (D is the internal diameter of the flow meter).
 - i. For convenient cleaning and maintenance of the flow meter, a bypass pipe must be installed.








- j. When installing the flow meter of the PTFE lining, the bolt connecting two flanges should be fastened evenly. Otherwise, it will damage the PTFE lining. Please use the torque wrench as much as possible.
- k. The flow meter should be protected from strong vibration and great temperature change. In the meantime, damage of the corrosive liquid on the flow meter should be prevented.
- l. If the flow meter is installed at a position with direct sunlight, shielding facilities should be set up.
- m. When installing the sensor, the measuring pipe and the process pipe must be on the same axial line. For the sensor with the nominal diameter of DN50 or below, the axial line deviation should not exceed 2mm. For those of DN65~DN150, the axial line deviation should not exceed 3mm. For those of $\geq$ DN200, the axial line deviation should not exceed 4mm.
- n. The shim installed between the flanges should have excellent anti-corrosion property. The shim should not intrude in the pipe, which will block the flowing fluidic
- o. Fasten the bolts and screws of the flow meter. The screw threads should be undamaged with good lubrication condition. The bolts with torque wrench must be fastened based on the flange size and torque.
- p. When welding or flame-cutting the pipes near the sensor, isolation measure must be conducted, so as to prevent the lining from heating. Moreover, the flow meter must be powered off, or it will damage the flow meter.

11.6 Notes for Installation on the Pipe

When installing the flow meter, one must follow the installation diagrams as shown below.

This will ensure the flow meter can guarantee the pipe is always filled with the liquid: (The figures below are only typical cases, which don't include all feasible installation methods.





The user may judge the installation position based on the actual condition.)

No.	Diagram	Description
1		■ It should be installed at the lower point and the vertically upward point of the horizontal pipe. ■ Don't install it at the highest point and the vertically downward point of the pipe.
2		■ It should be installed at the rising point of the pipe.
3		■ If the pipe gap exceeds 5m, the air release valve should be installed at the downstream of the sensor. The downstream of the sensor should have some back pressure.
4		■ The control valve and cut valve should be installed at the downstream of the sensor rather than the upstream.
5		■ The sensor should be installed at the pump outlet rather than the inlet.

11.7 Grounding Requirements

The grounding of the electromagnetic flow meter is very important. If the grounding is poor, it won't work normally. The sensor and transmitter should be equipped with high-quality independent grounding wire (The section area of the copper core is 1.6mm^2).

The grounding resistance should be $<10\Omega$.

	Diagram	Description
Grounding Ring		■ The grounding ring is needed if the pipe connecting with the sensor is insulating. ■ The same material as the electrode should be chosen, to prevent corrosion by the liquid. ■ If the test medium is abrasive, the neck grounding ring should be selected.
Grounding Method		■ It is for installing the flow meter on the metal pipe not coated with insulating layer.
		■ When installing the flow meter on the plastic pipe or the pipe with insulating coating material, paints or lining, grounding rings on both ends of the sensor should be installed.
		■ When installing the flow meter on the protective pipe of cathode, the pipe with the protection of electrolytic corrosion generally has insulating walls and external sides. Thus, during installation, the grounding ring and the flanges on the pipe should be insulating.


12. Wiring and Using

12.1 Wiring

12.1.1 Notes for Wiring


- It is recommended to select 2-core insulation rubber cable, with the external diameter larger than 10mm.
- For AC power supply, L1 should be connected with “Live Wire”.
- The wiring for all terminal blocks should be clapped with the flathead terminal and insulated. This ensures that the power cable does not extrude into the terminal block.
- The total impedance of the output cable on the current output terminal should be no more than the value stated in the specification.
- The pulse or frequency output is generally NPN transistor output, which requires external power supply.
- After the wiring is finished, the ends of the cable outlet should be fixed, so as to guarantee water-proof performance.

12.1.2 Diagram of Sensor Wiring Terminal




12.1.3 Diagram of Transmitter Wiring Terminal

AC100~240V




DC24V




Power Cable of Excitation Signal		Signal Measurement Power Cable	
Terminal Name	Description	Terminal Name	Description
F1	Excitation Signal Wire	E1	Detection Signal Wire
F2	Excitation Signal Wire	ES1	E1 Detection Signal Shielded Wire
S	Signal Shielded Wire	E2	Detection Signal Wire
		ES2	E2 Detection Signal Shielded Wire
		S	Signal Shielded Wire
		E3	Reserved code
		NC	Reserved code

the description of Input / Output signal terminal					
Terminal Name	Description		Terminal Name	Description	
-	Power Input V-		D+	RS-485 +	
+	Power Input V+		D-	RS-485 -	
PE	GND		DO1+	Alarm Output 1+	
			DO1-	Alarm Output 1-	
DI+	Digital Input +		DO2+	Alarm Output 2+	
DI-	Digital Input -		DO2-	Alarm Output 2-	
MA+	4-20mA Output +		AI+	4-20mA Input +	
MA-	4-20mA Output -		AI-	4-20mA Input -	
P+	Pulse Output +				
P-	Pulse Output -				

12.1.4 Signal Electrical Cable Wiring


Excitation Signal Wire					
(Unit: mm)					
					
Definition of wire cover color					
F1: Red	F2: Blue		F3: Bare copper wire		
Note 1: Euro-Type terminal spec.: F1, F2, S adopt dia. 1.0mm. Note 2: Attention Shield wire shall be alone can not shorted with others (showed as above diagram) (Suggest using heat-shrink tube for protection)					

(Unit: mm)					
					
Sensing Signal Wire					
Definition of wire cover color					
E1: Red	ES1: Bare copper wire	E2: Blue	F3: Bare copper wire	ES2: Bare copper wire	S: Bare copper wire
Note 1: Euro-Type terminal spec.: E1, E2, S adopt dia. 1.0mm; ES1 , ES2 adopt dia. 1.7mm. Note 2: Attention Shield wire shall be alone can not shorted with others (showed as above diagram) (Suggest using heat-shrink tube for protection)					

12.2 Input / Output Function Wiring

12.2.1 4-20mA Current output

4~20mA Output



Specifications:


Output mode: Active

Max load impedance: 700Ω

Max output current: 24mA

12.2.2 Pulse Output

Pulse Output



Specifications:

Output mode: Passive

Max output voltage: 32 VDC

Max input current: 200mA (Protection)


Max working frequency: $< 8000\text{ Hz}$

Min pulse width: 0.0625 ms

Pulse width control: Auto 50% duty

12.2.3 RS-485 Communication

RS-485 Communication




Specifications:


Terminal resistance: 120Ω

Max number of connected terminals: 256 (When the line impedance is matching)


12.2.4 Digital output 1 (DO1)




12.2.5 Digital output 1 (DO2)



12.2.6 Digital input (DI)



12.2.7 Analogy input (AI)




13. Inspection before Power-On


1. Check whether the flow meter is damaged during transportation and installation.
2. Check whether the voltage of the power supply is consistent with that specified on the nameplate.
3. Check whether the fuse used is of the correct current value.
4. Check whether the flow meter is grounded correctly.
5. Open the pipe valve to fill the pipeline system with liquid. One should pay attention to removing the leaked gas and residuals in the system.
6. Power on the flow meter to warm up for 10 minutes. Then it can work normally.

14. Parameter Functions

14.1 Procedure for Menu Setting



14.1.1 Functions of the Display Interface



14.1.2 Button Functions in Parameter Setting Status:

Button	Main Measuring Page	Menu Mode	Parameter Setting Page		
			Read Only	Number Edit Mode	List Edit Mode
ENT	Enter menu	Enter sub menu		Confirm button (Keep pressing)	Confirm button (Keep pressing)
←		Return to the previous page	Return to the previous page	"Left" button	Return to the previous page
↑		Sub menu option 【Down】		Number: "Plus" button	Option: Next page
ENT+ ←				Cancel	

14.2 Various Parameter Setting Ranges

Main Menu	Sub Menu	Unit	Default	Setting Range
Fast Set (0)	Device Tag Num (1.1)	The parameter is linking from standard menu		
	Zero Adj.(2.1)			
	Flow Span (1.5)			
	Flow Unit (1.4)			
	Low cutoff (2.4)			
	Damping Time (3.1)			
	Pulse Out Unit (3.3)			
	Total Reset (1.9)			

Main Menu	Sub Menu	Unit	Default	Setting Range
Basic Set (1)	Device Tag Num (1.1)	none	00001	00001~65535
	Measure Type (1.2)	-	Water	Water
	Tube Size (1.3)	mm	actual	10,15,25,32,40,50,65,80,100
				125,150,200,250,300,350,400,450,500
	Flow Unit (1.4)	-	m ³ /h	L/(s,min,h), m ³ /(s,min,h), gal/(s,min,h), kg(s,min,h), Ton(s,min,h) (Flow rate* Liquid density = weight) "L/s","L/m","L/h","m ³ /s","m ³ /m", "m ³ /h","gal/s","gal/m","gal/h","kg/s", "kg/m","kg/h","Ton/s","Ton/m", "Ton/h","m ³ /d"
	Flow Span (1.5)	=Flow Rate Unit	(5m/s) x (Diameter/2) ² x pi x Unit of Flow	(0.1 ~ 10.0m/s) x (Diameter/2) ² x pi x Unit of Flow (000.00)
	Direction (1.6)	dir	Forward	Forward,Reverse
	Total Unit (1.7)	-	m ³	Liter,gal, m ³ ,kg,Ton
	Total Mode (1.8)	none	Forward	Forward,Reverse,Bi-direction
	Total Reset (1.9)	none	Cancel	Cancel,Accept

Main Menu	Sub Menu	Unit	Default	Setting Range
Advanced Set (2)	Zero Adj. (2.1)	m/s	actual	-0.5000~+0.5000
	K-Factor (2.2)	none	1.000	0.000~3.000
	Density (2.3)	g/cm ³	1.0000	0.0001~9.9999
	Low cutoff (2.4)	%	0.5	0.00~100.00
	Fwd. Init. (2.5)	=Total Unit	0	0~9999999999
	Rev. Init. (2.6)	=Total Unit	0	0~9999999999

Main Menu	Sub Menu	Unit	Default	Setting Range
I/O Signal Set (3)	Damping Time (3.1)	second	3	0~100
	Pulse Out Mode (3.2)	none	Pulse NO	Pulse NO, Pulse NC, Frequency
	Pulse Out Unit (3.3)	Unit/pulse	0.1 L	0.001~100(L,gal, m ³ ,g,kg,Ton) L/pulse,gal/pulse, m ³ /pulse,g/pulse,kg/pulse, Ton/pulse
	Max. Freq. (3.4)	kHz	2K	0.001~8K (00.000)
	Curr. Mode (3.5)	none	4-20	4-20,0-20
	4mA Fine-Tune (3.6)	count	0	-5000~5000
	20mA Fine-Tune (3.7)	count	0	-5000~5000
	Input1 Func. (3.8)	N/A	None	None, Total Reset
	Input1 Type (3.9)	N/A	NO	NO,NC
	Filter Variation(3.10)	m/s	1	00.000~10.000
	Filter Weight(3.11)	%	10	0~100
	Median Filter(3.12)	%	Enable	Disable,Enable

Main Menu	Sub Menu	Unit	Default	Setting Range
Alarm Set (4)	Max. Flow (4.1)	Flow Rate Unit	Max.	Max. Flow Rate
	Min. Flow (4.2)	Flow Rate Unit	min.	Min. Flow Rate
	Empty Tube Set (4.3)	N/A	Enable	Enable, Disable
	Output 1 Func. (4.4)	N/A	Max. Flow Rate	Max. Flow Rate, Min. Flow Rate, Empty Tube, System Alarm
	Output 1 Type (4.5)	N/A	NO	NO,NC
	Output 2 Func. (4.6)	N/A	Min. Flow Rate	Max. Flow Rate, Min. Flow Rate, Empty Tube, System Alarm
	Output 2 Type (4.7)	N/A	NO	NO,NC
	Curr. Func. (4.8)	N/A	None	Empty Tube, System Alarm
	Alarm Curr. (4.9)	mA	3.6	3.6,3.8,20.5,22
	Temp. Alarm.(4.10)	N/A	1	0: OFF, 1: ON

Main Menu	Sub Menu		Unit	Default	Setting Range
System Set(5)	Language(5.1)	N/A	N/A	English	English,Traditional Chinese, Simplified Chinese
	System Info.(5.2)	Tube Status	N/A	Actual	Normal, Empty
		Resistance	m/s	Actual	N/A
		Status Code	kΩ	Actual	N/A
		Act. Flow Speed	N/A	Actual	0000 0000 ~ FFFF FFFF
	Self-Test(5.3)	N/A	N/A	Cancel	Normal, Circuit Fail ,Excitation Fail, Amb. Temp, Electrode Coating
	Analogy Input(5.4)	4mA Display	N/A	0000	0~9999
		20mA Display.	N/A	1000	0~9999
		4-20mA Unit	N/A	Kpa	None, Kpa, Mpa, Psi, Bar, °C, °F
		Dot	N/A	1	0~3
	ModBus Comm.(5.5)	BaudRate(2.13.2)	N/A	1	1~255
		Modbus ID(2.13.1)	BPS	9600	1200,2400,4800,9600,19200, 38400,57600
		Stop bit(2.13.5)	N/A	8	8,9
		Data bit(2.13.3)	N/A	none	none,odd,even
		Parity(2.13.4)	N/A	1	1,2
	Recovery Default(5.6)	N/A	N/A	Cancel	Cancel, Accept
	Mains Frequency(5.7)	N/A	Hz	50	50, 60
	LCM Contrast Brightness(5.8)	N/A	N/A	32	15~40
Manu Password (5.9)	User Password(5.9.1)	N/A	00000	0~99999	
	Admin Password(5.9.2)				

Main Menu	Sub Menu	Unit	Default	Setting Range
Simulation(6)	Flow Speed(6.1)	m/s	0	-10 ~ 10
	Flow Rate(6.2)	unit of flow	0	0~Max.
	Output Curr.(6.3)	mA	4mA	3.6~22
	Output Freq.(6.4)	Hz(pulse/sec)	2	2~8000
	Output1 Status(6.5)	N/A	OFF	ON/OFF
	Output2 Status(6.6)	N/A	OFF	ON/OFF
	Input1 Status(6.7)	N/A	Actual	ON/OFF
	Input Curr.(6.8)	N/A	Actual	0~24mA

Main Menu	Sub Menu	Unit	Default	Setting Range
System Log (7)	Date Set(7.1)	N/A	Actual	Year : 17~99, Month : 01~12, Day: 01~31
	Time Set(7.2)	N/A	Actual	Hour: 00~23, Minute : 00~59, Second : 00~59
	Log data clear (7.3)	N/A	Cancel	Cancel, Accept
	System Log Info (7.4)	N/A	Actual	N/A

Main Menu	Sub Menu	Unit	Default	Setting Range
Information(8)	F.W. Version(8.1)		actual	

※Sub menu 1.3、1.9、2.2、2.5、2.6、5.6、5.9、7.3, only the admin can change.

14.3 System record illustration

Display image illustration

① 2021/07/09 18:19:54 ⑤ ② Device Tag No. ③ Data : 2 ④ User 0067/0067 ⑥ System Log 7.4 2021/07/09 18:11:52 ⑦ Power on ④ System 0066/0066	
Item	Description
1	Date of event occurred
2	Name of modified parameter, modifier is "User", "Admin"
3	The contents of modified parameter
4	Operator for modifying parameters, divided into "User", "Admin", and "System"
5	Time of event occurred
6	Current total number of records
7	Names of system events, the modification is by "System", see the table below for details

Classification	Message	Description
Hardware status"	Power on	Record the current time when the system is booted"
	Power off	Record the current time when the system is shut down"
User setting"	Total reset	Only permitted when user is "Admin"
	K-Factor	Only permitted when user is "Admin"
	Tube size	Only permitted when user is "Admin"
	Admin password	Only permitted when user is "Admin"
	User password	Permitted for both ""User"" or "Admin"
	Set default	Only permitted when user is "Admin"
	Others	Refer to the parameter setting function description 14.2 for the authority classification."

15. Ordering Information

Model Number	Order Code
EPD30	EPD10000-A
EPD34	EPD10400-A

EPD1

05

06

00

-

A

10

11

12

13

14

15

16

17

18

19

20

21

A

23

24

25

26

27

28

05

06

Type

00: Integrated type

04: Remote type

10

11

12

Pipe diameter

015: 15mm

025: 25mm

040: 40mm

050: 50mm

065: 65mm

080: 80mm

100: 100mm

125: 125mm

150: 150mm

200: 200mm

250: 250mm

300: 300mm

350: 350mm

400: 400mm

450: 450mm

500: 500mm

13

14

15

Connection specification

C48: ANSI B16.5 Class 150

C49: ANSI B16.5 Class 300

A41: JIS B2220 7.5K

A42: JIS B2220 10K

A45: JIS B2220 20K

D57: DIN 2501 PN10

D58: DIN 2501 PN16

D60: DIN 2501 PN40

16

17

Casing and flange

MD: Carbon steel

MA: SUS304

MC: SUS316L

18

19

Lining material

08: Neoprene (Min. DN40)

21: PTFE (Min. DN15)(Accuracy of 0.2% and 0.3% can only be achieved using PTFE material)

37: NBR (Min. DN40)

(Next page)

EPD1 ⁰⁵☐ ⁰⁶☐ 0 0 - A ¹⁰☐ ¹¹☐ ¹²☐ ¹³☐ ¹⁴☐ ¹⁵☐ ¹⁶☐ ¹⁷☐ ¹⁸☐ ¹⁹☐ ²⁰☐ ²¹☐ A ²³☐ ²⁴☐ ²⁵☐ ²⁶☐ ²⁷☐ ²⁸☐

²⁰ ²¹ **Electrode material**

MC: SUS316L

MF: Titanium

MK: Tantalum

MJ: Hastelloy alloy(C-276)

²³ **Power supply**

A: 100~240Vac, 50/60Hz

D: 24Vdc

²⁴ **Accuracy**

F: 0.5%

G: 0.3%

H: 0.2%

²⁵ ²⁶ **Grounding material**

00: None

MA: SUS304

MC: SUS316L

MF: Titanium

MK: Tantalum

MJ: Hastelloy alloy(C-276)

²⁷ ²⁸ **Cable length**

00: None(Standard type only)

10: 10 M(Standard)

15: 15 M

20: 20 M

.

.

.

95: 95 M

A0: 100 M

16. Transportation and Storage

To prevent the flow meter from damage during the transportation, please keep the packaging condition as how it was when it was shipped from the factory before arriving at the installation site. The storage conditions should meet the following:

- Appropriate rainproof and damp-proof treatment must be conducted .
- Vibration must be reduced and collision with other objects must be prevented during its transportation.
- The storage temperature must be in the range of -20~70°C
- The humidity should be lower than 80%
- To store the used sensors, clean the tested medium attached on the lining and the electrode, and avoid oxidation by not exposing it to too much air for a long time.
- Outdoor storage may degrade the performance of the flow meter.

17. Fault Inspection and Repair

When fault occurs to the flow meter or it fails to meet the accuracy requirements, please try to fix it by referring to the table below.

Fault	Inspection	Solution
Inaccuracy	Is the flowmeter's zero point shifting?	Perform zero-point calibration. Refer to the menu. Ensure the pipe is fully filled with liquid and there is no liquid flo
	Is the pipe fully filled with liquid?	Adjust the installation position to ensure the pipe is
	Is the flowmeter operating near its upper or lower flow range	Adjust the flow rate to be between 1 m/s and 10 m/s.
	Is the range setting correct?	Ensure the flowmeter's range matches the range set in the.
	Are the output connections of the flowmeter correct?	Reconnect and ensure the wiring is smooth.receiving
	Is the grounding between the flowmeter and the pipeline proper?	Correctly ground the flowmeter, ensuring the resistance does not exceed 10Ω.
	Is the sensor K-coefficient value consistent with the sensor label? nameplate.	If the K-coefficient has been altered, restore it to the original value.
No Display on Startup	Are the power supply, switch, and fuse functioning properly?	- Resolve power supply issues so the flowmeter can obtain power correctly. - The flowmeter might be damaged. Contact the original manufacturer or reseller.
Communication Failure	Is the RS-485 communication functioning?	- Confirm that the RS-485 converter is working correctly. - Are the RS-485 bit format/ID/ baud rate parameters correct?
No Pulse Output	Is there an external 12VDC power supply to the output terminal?	Factory default is NO power supply passive NPN output; external power is required.

Unstable Display Values	■ Is the liquid in the pipeline of low conductivity?	■ Compare with the pipeline material characteristics.
	■ Is the grounding ring missing or poorly connected?	■ Check the order details. Regardless of the pipe material, there must be a grounding ring. Please read the operation manual on how to use it.
	■ Is the flowmeter installed near a high-voltage interference zone?	■ Reroute the signal or power lines away from the
	■ Is moisture or condensation causing interference in an empty pipe?	■ Enable empty pipe alarms.
	■ Is there leakage voltage in the flowmeter power live wire?	■ Reroute the power supply line and reset the flowmeter to factory settings. Reconfigure parameters such as pipe size and K-factor.
	■ The transmitter or main circuit board might be damaged.	■ Replace with the spare circuit board or contact the manufacturer.
Flow is Present but No Flow Value Displayed	■ Is the low flow cut-off value (shield value) higher than the current flow?	■ Adjust and lower the cut-off value (refer to factory settings).
	■ Are the signal and excitation wires in the separated flowmeter functioning properly?	■ Verify correct wiring and tighten the terminal blocks at both ends.
	■ Is the sensor arrow aligned with the pipeline flow direction?	■ Confirm the sensor orientation and set the fluid flow direction correctly.
	■ Is the pipeline filled with liquid?	■ Ensure that the sensor is installed at the concave part of the horizontal pipeline or at a raised section behind the pipeline. Ensure that the pipe is full.
Abnormal Messages on Display	■ Refer to the manual for abnormal message descriptions.	■ Follow the manual's troubleshooting instructions.

Flowmeter Inner Lining Raised Up	■ Is negative pressure causing the issue?	■ Remove the negative pressure or consider switching to another product.
Abnormal 4-20mA Output	■ Is there no current output?	■ Remove the existing wiring and test with a handheld multimeter. Confirm the product functionality. ■ Restore factory settings and retest. ■ Contact local technical personnel if the issue
Large Measurement Error	■ Are the filter settings incorrect?	■ Reduce the signal averaging time and disable the median filter function.
	■ Are there deposits on the lining or electrodes?	■ Inspect and clean any deposits on the electrodes.
	■ If the above-mentioned checkings are not found;	■ Contact local technical personnel for further assistance.

Error code description

Warning status	Directions
Empty Tube	When measuring, there is no liquid in the pipe, or the liquid conductivity is below 5μs/cm
Sensor Discon.	The sensor is not properly connected, or the excitation current is abnormal, making it unable to detect the flow correctly.
Electrode Coating	The electrodes are severely covered with non-conductive substances.
Init. Comm. Err.	Internal malfunction. (Please try restarting.)

18. MODBUS Communication Protocol

Address(Hex)	Address(Dec)	Variable Name	Data Type	Unit	Range	Definition	Authority
0x1000	4096	gt_modbus_slave_fine_tek_id[0]	UINT8	N/A		"FI"	Read only(Header)
0x1001	4097	gt_modbus_slave_fine_tek_id[2]	UINT8	N/A		"NE"	Read only(Header)
0x1002	4098	gt_modbus_slave_fine_tek_id[4]	UINT8	N/A		"-T"	Read only(Header)
0x1003	4099	gt_modbus_slave_fine_tek_id[6]	UINT8	N/A		"EK"	Read only(Header)
0x1004	4100	PFC_PRODUCT_TYPE	UINT16	N/A		"FM"	Read only(Header)
0x1005	4101	PFC_PRODUCT_NUMBER	UINT16	N/A		0x0001	Read only(Header)
0x1006	4102	PFC_PRODUCT_VERSION	UINT16	N/A		0x0001	Read only(Header)

0x1010	Measuring Status		Data Type	Unit	Range	Definition	Authority
0x1010	4112	PFC_FlowTotal_FRAM_FWD_VAL-High	FLOAT64	m³		Forward accumulated flow capacity	Read only
0x1011	4113	PFC_FlowTotal_FRAM_FWD_VAL+1					Read only
0x1012	4114	PFC_FlowTotal_FRAM_FWD_VAL+2					Read only
0x1013	4115	PFC_FlowTotal_FRAM_FWD_VAL-Low					Read only
0x1014	4116	PFC_FlowTotal_FRAM_REV_VAL-High	FLOAT64	m³		Backward accumulated flow capacity	Read only
0x1015	4117	PFC_FlowTotal_FRAM_REV_VAL+1					Read only
0x1016	4118	PFC_FlowTotal_FRAM_REV_VAL+2					Read only
0x1017	4119	PFC_FlowTotal_FRAM_REV_VAL-Low					Read only
0x1018	4120	PFC_FlowTotal_FRAM_BI_DIR_VAL-High	FLOAT64	m³		Two-way accumulated flow capacity	Read only
0x1019	4121	PFC_FlowTotal_FRAM_BI_DIR_VAL+1					Read only
0x101A	4122	PFC_FlowTotal_FRAM_BI_DIR_VAL+2					Read only
0x101B	4123	PFC_FlowTotal_FRAM_BI_DIR_VAL-Low					Read only
0x101C	4124	PFC_FlowRate_Main_Val-High	FLOAT64	Rate Unit		Instant flow rate value	Read only
0x101D	4125	PFC_FlowRate_Main_Val+1					Read only
0x101E	4126	PFC_FlowRate_Main_Val+2					Read only
0x101F	4127	PFC_FlowRate_Main_Val-Low					Read only
0x1020	4128	gb_pfc_flowrate_rawdata_m_s-High	FLOAT64	m/s		\Setting\ Information\ Actual flow rate	Read only
0x1021	4129	gb_pfc_flowrate_rawdata_m_s+1					Read only
0x1022	4130	gb_pfc_flowrate_rawdata_m_s+2					Read only
0x1023	4131	gb_pfc_flowrate_rawdata_m_s-Low					Read only
0x1024	4132	gf_pfc_current_out_value-High	FLOAT32	mA		Output current value	Read only
0x1025	4133	gf_pfc_current_out_value-Low					Read only
0x1026	4134	PFC_SIMULATION_INPUT_CURR-High	FLOAT32	mA		lutput current value	Read only
0x1027	4135	PFC_SIMULATION_INPUT_CURR-Low					Read only
0x1028	4136	gb_pfc_liquid_resistance-High	FLOAT32	KΩ		\Setting\ Information\ Liquid resistance value	Read only
0x1029	4137	gb_pfc_liquid_resistance-Low					Read only
0x102A	4138	PFC_FlowTotal_FWD_VAL-Low	UINT32	Liter		Forward accumulated flow capacity	Read only
0x102B	4139	PFC_FlowTotal_FWD_VAL-High					Read only
0x102C	4140	PFC_FlowTotal_REV_VAL-Low	UINT32	Liter		Backward accumulated flow capacity	Read only
0x102D	4141	PFC_FlowTotal_REV_VAL-High					Read only
0x102E	4142	PFC_FlowTotal_BI_VAL-Low	UINT32	Liter		Two-way accumulated flow capacity	Read only
0x102F	4143	PFC_FlowTotal_BI_VAL-High					Read only
0x1030	4144	PFC_Flowrate_Main_Vluae-Low	FLOAT32	Rate Unit		Instant flow rate value	Read only
0x1031	4145	PFC_Flowrate_Main_Vluae-High					Read only
0x1032	4146	PFC_Flowrate_rawdata_vluae-Low	FLOAT32	m/s		\Setting\ Information\ Actual flow rate	Read only
0x1033	4147	PFC_Flowrate_rawdata_vluae-High					Read only

0x1040	System status		Data Type	Unit	Range	Definition	Authority
0x1040	4160	PFC_TEMPERATURE_BOARD_NOW-High	FLOAT32	°C		PCB temp.	Read only
0x1041	4161	PFC_TEMPERATURE_BOARD_NOW-Low					Read only
0x1042	4162	PFC_SELF_TEST_TUBE_STATUS	UINT16	N/A	0: Normal 1: Empty	\Setting\ Information\ Status of pipe	Read only
0x1043	4163	pfc_system_status_code_value-High	UINT32	N/A		\Setting\ Information\ system status code	Read only
0x1044	4164	pfc_system_status_code_value-Low					Read only

0x1050	Paramter setting- System information		Data Type	Unit	Range	Definition	Authority
0x1050	4176	PFC_PRODUCT_VERSION	UINT16	N/A		Version of firmware (Master)	Read only

0x1055	Parameter setting- Basic setting		Data Type	Unit	Range	Definition	Authority
0x1055	4181	PFC_BASIC_SET_DEVICE_TAG_NUM	UINT16	N/A	00001~65535(Default:1)	Basic setting/ ID number	Read /Write
0x1056	4182	PFC_BASIC_SET_MEASURE_TYPE		N/A	0:Water 1:none	Measured object	Read /Write
0x1057	4183	PFC_BASIC_SET_TUBE_SIZE-High	FLOAT32	10~100mm	Line size divided by 1000	Basic setting/ Connection size	Read /Write
0x1058	4184	PFC_BASIC_SET_TUBE_SIZE-Low		125~500mm	e.g.: DN80= 80/1000=0.08		
0x1059	4185	PFC_BASIC_SET_FLOW_RATE_UNIT	UINT16	N/A	0:L/m 1:L/h 2:m3/m 3:m3/h 4:gal/m 5:gal/h 6:kg/m 7:kg/h 8:T/m 9:T/h 10:m3/d	Basic setting/Instant flow rate unit	Read /Write
0x105A	4186	PFC_BASIC_SET_FLOW_SPAN-High	FLOAT64	m³/s	+Line size(m)^2 *0.0785 ~ Line size(m)^2 *7.85	Basic setting/Measuring range of full pipe	Read /Write
0x105B	4187	PFC_BASIC_SET_FLOW_SPAN+1					Read /Write
0x105C	4188	PFC_BASIC_SET_FLOW_SPAN+2					Read /Write
0x105D	4189	PFC_BASIC_SET_FLOW_SPAN-Low					Read /Write
0x105E	4190	PFC_BASIC_SET_FLOW_DIR	UINT16	N/A	0: Forward 1: Backward	Basic setting/Flow direction	Read /Write
0x105F	4191	PFC_BASIC_SET_FLOW_TOTAL_UNIT	UINT16	N/A	0:Liter1:gal2:m33:kg4:Ton	Basic setting/ Accumulated flow capacity unit	Read /Write
0x1060	4192	PFC_BASIC_SET_TOTAL_MODE	UINT16	N/A	0: Forward 1: Backward 2: Two-way	Basic setting/ Accumulated flow capacity mode	Read /Write
0x1061	4193	PFC_BASIC_SET_TOTAL_RESET	UINT16	N/A	0: Cancel 1: Confirm	Basic setting/ Reset accumulated flow capacity	Read /Write

0x1070	Parameter setting- Advanced setting		Data Type	Unit	Range	Definition	Authority
0x1070	4208	PFC_BASIC_SET_ZERO_ADJ-High	FLOAT64	m/s	-0.5000~+0.5000	Basic setting/ Zero point setting	Read /Write
0x1071	4209	PFC_BASIC_SET_ZERO_ADJ+1					Read /Write
0x1072	4210	PFC_BASIC_SET_ZERO_ADJ+2					Read /Write
0x1073	4211	PFC_BASIC_SET_ZERO_ADJ-Low					Read /Write
0x1074	4212	PFC_BASIC_SET_K_FACTOR-High	FLOAT64	N/A	+0.0000~+3.0000 (Default:1.0)	Basic setting/ K Factor setting	Read /Write
0x1075	4213	PFC_BASIC_SET_K_FACTOR+1					Read /Write
0x1076	4214	PFC_BASIC_SET_K_FACTOR+2					Read /Write
0x1077	4215	PFC_BASIC_SET_K_FACTOR-Low					Read /Write
0x1078	4216	PFC_ADVANCED_SET_DENSITY-High	FLOAT64	g/cm ³	+0.0001~+9.9999 (Default:1.0)	Basic setting/ Density	Read /Write
0x1079	4217	PFC_ADVANCED_SET_DENSITY+1					Read /Write
0x107A	4218	PFC_ADVANCED_SET_DENSITY+2					Read /Write
0x107B	4219	PFC_ADVANCED_SET_DENSITY-Low					Read /Write
0x107C	4220	PFC_BASIC_SET_LOW_FLOW_CUTOFF-High	FLOAT64	%	+0.0000~+100.00 (Default:0.5)	Basic setting/ Low rate shield	Read /Write
0x107D	4221	PFC_BASIC_SET_LOW_FLOW_CUTOFF+1					Read /Write
0x107E	4222	PFC_BASIC_SET_LOW_FLOW_CUTOFF+2					Read /Write
0x107F	4223	PFC_BASIC_SET_LOW_FLOW_CUTOFF-Low					Read /Write
0x1080	4224	PFC_ADVANCED_SET_FWD_TOTAL_INIT-High	FLOAT64	m ³	0~99999	Advanced setting/ Forward accumulated flow ratestart value	Read /Write
0x1081	4225	PFC_ADVANCED_SET_FWD_TOTAL_INIT+1					Read /Write
0x1082	4226	PFC_ADVANCED_SET_FWD_TOTAL_INIT+2					Read /Write
0x1083	4227	PFC_ADVANCED_SET_FWD_TOTAL_INIT-Low					Read /Write
0x1084	4228	PFC_ADVANCED_SET_REV_TOTAL_INIT-High	FLOAT64	m ³	0~99999	Advanced setting/ Backward accumulated flow ratestart value	Read /Write
0x1085	4229	PFC_ADVANCED_SET_REV_TOTAL_INIT+1					Read /Write
0x1086	4230	PFC_ADVANCED_SET_REV_TOTAL_INIT+2					Read /Write
0x1087	4231	PFC_ADVANCED_SET_REV_TOTAL_INIT-Low					Read /Write
0x1088	4232		UINT16	N/A	0~1	Zero point auto calibration ON/OFF	Read /Write

0x1090	Parameter setting- Output/Input signal setting		Data Type	Unit	Range	Definition	Authority
0x1090	4240	PFC_IO_SIGNAL_SET_DAMPING_TIME	UINT16	Second	000~+100(Default:3)	Output/Input signal setting/ Input signal average time	Read /Write
0x1091	4241	PFC_IO_SIGNAL_SET_PULSE_OUTPUT_MODE	UINT16	N/A	0:NO 1:NC 2: Frequency output	Pluse output mode	Read /Write
0x1092	4242	PFC_IO_SIGNAL_SET_PULSE_OUTPUT_UNIT-High	FLOAT64	Liter	+0.0010~+99.999 (Default:0.01)	Pluse unit setting	Read /Write
0x1093	4243	PFC_IO_SIGNAL_SET_PULSE_OUTPUT_UNIT+1					Read /Write
0x1094	4244	PFC_IO_SIGNAL_SET_PULSE_OUTPUT_UNIT+2					Read /Write
0x1095	4245	PFC_IO_SIGNAL_SET_PULSE_OUTPUT_UNIT-Low					Read /Write
0x1096	4246	PFC_IO_SIGNAL_SET_MAX_FREQ-High	FLOAT64	Hz	+0.0010~8.000 (Default:2.0)	Frequency setting	Read /Write
0x1097	4247	PFC_IO_SIGNAL_SET_MAX_FREQ+1					Read /Write
0x1098	4248	PFC_IO_SIGNAL_SET_MAX_FREQ+2					Read /Write
0x1099	4249	PFC_IO_SIGNAL_SET_MAX_FREQ-Low					Read /Write
0x109A	4250	PFC_IO_SIGNAL_SET_OUTPUT_CURR_MODE	UINT16	mA	0: 4-20mA 1: 0-20mA	Current output mode	Read /Write
0x109B	4251	PFC_IO_SIGNAL_SET_4MA_FINE_TUNE	INT16	Count	-5000.0~+5000.0 (Default:0)	4mA output adjustment	Read /Write
0x109C	4252	PFC_IO_SIGNAL_SET_20MA_FINE_TUNE	INT16	Count	-5000.0~+5000.0 (Default:0)	20mA output adjustment	Read /Write
0x109D	4253	PFC_IO_SIGNAL_SET_DIGITAL_1_IN_FUNC	UINT16	N/A	0: none 1: Reset	Input1 contact function	Read /Write
0x109E	4254	PFC_IO_SIGNAL_SET_DIGITAL_1_IN_TYPE	UINT16	N/A	0:NO 1:NC	Input1 contact form	Read /Write

0x10A5	Parameter setting- Alarm setting		Data Type	Unit	Range	Definition	Authority
0x10A5	4261	PFC_ALARM_SET_MAX_FLOW_RATE-High	FLOAT64	m³/s	+0.0000 ~ Line size(m)^2 *7.85	Max. flow rate	Read /Write
0x10A6	4262	PFC_ALARM_SET_MAX_FLOW_RATE+1					Read /Write
0x10A7	4263	PFC_ALARM_SET_MAX_FLOW_RATE+2					Read /Write
0x10A8	4264	PFC_ALARM_SET_MAX_FLOW_RATE-Low					Read /Write
0x10A9	4265	PFC_ALARM_SET_MIN_FLOW_RATE-High	FLOAT64	m³/s	+0.0000 ~ Line size(m)^2 *7.85	Min. flow rate	Read /Write
0x10AA	4266	PFC_ALARM_SET_MIN_FLOW_RATE+1					Read /Write
0x10AB	4267	PFC_ALARM_SET_MIN_FLOW_RATE+2					Read /Write
0x10AC	4268	PFC_ALARM_SET_MIN_FLOW_RATE-Low					Read /Write
0x10AD	4269	PFC_ALARM_SET_EMPTY_TUBE_DETECT	UINT16	N/A	0: Off 1: On	Empty pipe detection	Read /Write
0x10AE	4270	PFC_ALARM_SET_ALARM_1_FUNC	UINT16	N/A	0: None 1: Max. flow rate 2: Min. flow rate 3: Empty alarm 4: System error	Output 1 contact function	Read /Write
0x10AF	4271	PFC_ALARM_SET_ALARM_1_TYPE	UINT16	N/A	0:NO 1:NC	Output1 contact form	Read /Write
0x10B0	4272	PFC_ALARM_SET_ALARM_2_FUNC	UINT16	N/A	0: None 1: Max. flow rate 2: Min. flow rate 3: Empty alarm 4: System error	Output 2 contact function	Read /Write
0x10B1	4273	PFC_ALARM_SET_ALARM_2_TYPE	UINT16	N/A	0:NO 1:NC	Output2 contact form	Read /Write
0x10B2	4274	PFC_ALARM_SET_CURR_FUNC	UINT16	N/A	0: none 1: Empty alarm 2: System error	Alarm current function	Read /Write
0x10B3	4275	PFC_ALARM_SET_ALARM_CURR_VAL	UINT16	mA	0:3.6 1:3.8 2:20.5 3:22	Alarm current setting	Read /Write

0x10B9	Parameter setting- System setting		Data Type	Unit	Range	Definition	Authority
0x10B9	4281	PFC_SYSTEM_SET_LANGUAGE	UINT16	N/A	0: English 1: Chinese (Traditional) 2: Chinese (Simple)	Language	Read /Write
0x10BA	4282	PFC_SYSTEM_SET_ANALOGY_INPUT_4MA INFO-High	FLOAT32	N/A	0~9999	Analog setting/ 4 mA Value	Read /Write
0x10BB	4283	PFC_SYSTEM_SET_ANALOGY_INPUT_4MA INFO-Low					
0x10BC	4284	PFC_SYSTEM_SET_ANALOGY_INPUT_20M A INFO-High	FLOAT32	N/A	0~9999	Analog setting/ 20 mA Value	Read /Write
0x10BD	4285	PFC_SYSTEM_SET_ANALOGY_INPUT_20M A INFO-Low					
0x10BE	4286	PFC_SYSTEM_SET_ANALOGY_INPUT_4_2 0MA_UNIT	UINT16	N/A	0:None 1:Kpa 2:Mpa 3:Psi 4:Bar 5:°C 6:°F	4~20 mA input unit	Read /Write
0x10BF	4287	PFC_SYSTEM_SET_ANALOGY_INPUT_DOT	UINT16	N/A	0~3	Decimal digits	Read /Write
0x10C0	4288	PFC_IO_SIGNAL_SET_MODBUS_COMM_ID	UINT16	N/A	0 ~ 255	Modbus ID	Read /Write
0x10C1	4289	PFC_IO_SIGNAL_SET_MODBUS_COMM_B AUDRATE-High	UINT32	BPS	1200 :1200bps 2400 :2400bps 4800 :4800bps 9600 :9600bps 19200 :19200bps 38400 :38400bps 57600 :57600bps	BaudRate	Read /Write
0x10C2	4290	PFC_IO_SIGNAL_SET_MODBUS_COMM_B AUDRATE-Low					
0x10C3	4291	PFC_IO_SIGNAL_SET_MODBUS_COMM_D ATA_BITS	UINT16	N/A	0x0000:8 0x1000:9	Data bit	Read /Write
0x10C4	4292	PFC_IO_SIGNAL_SET_MODBUS_COMM_ST OP_BITS	UINT16	N/A	0x0000:1 0x2000:2	Stop bit	Read /Write
0x10C5	4293	PFC_IO_SIGNAL_SET_MODBUS_COMM_P ARITY	UINT16	N/A	0x0000:None 0x0400:even parity 0x0600:uneven parity	Parity	Read /Write
0x10C6	4294	PFC_LOAD_DEFAULT_SETTING	UINT16		0: Cancel 1: Confirm	Default value	Read /Write

0x10C9	Parameter setting- Analog Simulation		Data Type	Unit	Range	Definition	Authority
0x10C9	4297	PFC_SIMULATION_FUNC_STATE	UINT16	N/A	0:None 1: Flow rate 2: Flow capacity 3: Current output 4: Frequency output 5: Output1 status 6: Output2 status	Simulation fuction select	Read /Write
0x10CA	4298	PFC_SIMULATION_FLOW_SPEED-High	FLOAT64	m/s	-10.000~10.000	Simulation of flow rate	Read /Write
0x10CB	4299	PFC_SIMULATION_FLOW_SPEED+1					Read /Write
0x10CC	4300	PFC_SIMULATION_FLOW_SPEED+2					Read /Write
0x10CD	4301	PFC_SIMULATION_FLOW_SPEED-Low					Read /Write
0x10CE	4302	PFC_SIMULATION_FLOW_RATE-High	FLOAT642	Rate Unit	+0.0000 ~ Caliver(m)^2 *7.85	Simulation of flow capacity	Read /Write
0x10CF	4303	PFC_SIMULATION_FLOW_RATE+1					Read /Write
0x10D0	4304	PFC_SIMULATION_FLOW_RATE+2					Read /Write
0x10D1	4305	PFC_SIMULATION_FLOW_RATE-Low					Read /Write
0x10D2	4306	PFC_SIMULATION_OUTPUT_CURR-High	FLOAT32	mA	3.6~22	Simulation of current output	Read /Write
0x10D3	4307	PFC_SIMULATION_OUTPUT_CURR-Low					Read /Write
0x10D4	4308	PFC_SIMULATION_OUTPUT_FREQ	UINT16	KhZ	0.002~8KhZ	Simulation of frequency output	Read /Write
0x10D5	4309	PFC_SIMULATION_OUTPUT_1_STATUS	UINT16	N/A	0: OPEN 1: CLOSED	Simulation of output1 status	Read /Write
0x10D6	4310	PFC_SIMULATION_OUTPUT_2_STATUS	UINT16	N/A	0: OPEN 1: CLOSED	Simulation of output2 status	Read /Write

0x10DE	System specific setting		Data Type	Unit	Range	Definition	Authority
0x10DE	4318	PFC_SAVE_SYSTEM_VAR_TO_EEPROM	UINT16	N/A	0: none 1: Input	Input USER EEPROM	Read /Write
0x10DF	4319	PFC_ENG_MODE_SAVE_SETTING	UINT16	N/A	0: none 1: Input	Input FACTORY; Set EEPROM	Read /Write
0x10E0	4320	pfc_auto_set_excition_freq_flag	UINT16	N/A	0: Off 1: On	Auto input excitation frequency accoring to frequency and pipe size	Read /Write



EPD34 電磁流量計

產品操作手冊



桓達科技股份有限公司

23678 新北市土城工業區自強街 16 號

電話：886-2-22696789

網址：<http://www.fine-tek.com>

傳真：886-2-22686682

E-mail:info@fine-tek.com

目錄

1. 閱讀標示	3
2. 產品保證	5
2.1 新品保固	5
2.2 維修保固	5
2.3 服務網絡	6
3. 產品檢查	7
3.1 物品核對	7
3.2 安全查驗	7
4. 概述	7
5. 產品特點	8
6. 適用範圍	8
7. 環境條件	8
8. 工作原理	9
9. 技術性能	10
9.1 基本參數和性能指標	10
9.1.1 產品技術規格表	10
9.1.2 精度等級與允許誤差	11
9.1.3 各管徑建議流量範圍	11
9.1.4 各管徑耐壓及內徑規格	12
9.1.5 內襯材料	12
9.1.6 電極材料	13
9.1.7 外殼防護等級	13
9.2 執行標準	13
10. 外型尺寸	14
10.1 JIS 7.5K & 10K & 20K	14
10.2 ANSI 150LBS & 300LBS	16
10.3 DIN PN40 & PN16 & PN10	17
11. 安裝	18
11.1 保證電磁流量計測量精度的必要條件	18
11.2 安全措施	18
11.3 安裝前的檢查	18
11.4 吊裝	19
11.5 正確安裝	19
11.6 管道上安裝注意事項	21
11.7 接地要求	22
12. 接線與使用	23
12.1 訊號接線	23
12.1.1 接線注意事項	23
12.1.2 傳感器接線端子說明圖示	23
12.1.3 傳送器接線端子說明圖示	24

12.1.4 訊號電纜線接線說明	26
12.2 輸出入功能接線說明.....	27
12.2.1 4-20mA Current output	27
12.2.2 Pulse Output.....	27
12.2.3 RS-485 Communication	28
12.2.4 Digital output 1 (DO1).....	28
12.2.5 Digital output 2 (DO2).....	28
12.2.6 Digital input (DI).....	29
12.2.7 Analogy input (AI)	29
13. 送電前的檢查	29
14. 參數功能說明	30
14.1 設定選單流程說明	30
14.1.1 顯示介面功能	30
14.1.2 參數設定狀態時的鍵功能：	30
14.2 各參數設定功能說明.....	31
14.3 系統紀錄說明	39
15. 產品選型	41
16. 運輸與貯存.....	43
17. 故障檢查與維修.....	44
18. MODBUS 通訊協定(參照英文版)	45

1. 閱讀標示

感謝您購買本公司桓達科技的產品，此操作說明書是針對產品的特性、動作原理、操作和

維修方式，還有使用注意事項等內容來說明，可讓使用者充分瞭解產品的正確使用方法，避免發生設備損壞或操作者受傷等危險狀況。

- 使用本產品前，請完整、仔細的閱讀本操作手冊。
- 若本操作手冊無法提供您所要的需求時，請與本公司聯絡。
- 本操作說明書的內容，會依照版本的更新而有所不同，將會上傳於本公司網站上，提供使用者下載。
- 請不要自行拆開或維修，這意味著您將失去保固資格。請將產品寄回本公司維修和校準，或與本公司聯絡。
- 警告符號說明：



提示危險→表示若操作錯誤會有致命和重大災害的危險。



提示注意→表示若操作錯誤會有一定程度的傷害和設備的損壞。



提示電擊→表示可能會觸電的警告。



提示火災→表示可能會發生火災的警告。



提示禁止→表示禁止的錯誤動作事項。

2. 產品保證

2.1 新品保固

- 本公司產品於交貨日算起十二個月內，在符合保固條件之下發生故障，可不收檢測、零件、維修等費用。
- 產品運送過程導致新品瑕疵而非人為故障，可於 7 日內向本公司更換。
- 產品故障需寄回原廠維修時，請將產品整組寄回，勿自行拆卸部品，並且包裝請務必完善，避免運送損毀，造成更大的損失。
- 產品保證僅針對正常使用客戶，如有特殊應用、不正常使用及超量使用者，則不在此保證範圍內。
- 在以下狀況下發生故障，將不具有保固條件，需酌收檢測、零件、維修等費用：
 - 產品整機或零件超過保固期限。
 - 未依操作手冊使用或未依說明書上之使用環境，所致之故障毀壞。
 - 產品之毀損係受不可抗力(天災、水災、火災、地震、雷擊、颱風等)，人為破壞(刮傷、摔傷、卡榫斷裂、敲打、破裂、重擊等)，人為疏失(使用不合適的電壓、高濕、進水、汙漬、腐蝕、遺失、未妥善保管等)或其他非正常因素所致者。遭遇天災地變之不可抗拒之外力的情況下，所造成的故障。
 - 客戶擅自或使第三人安裝、添附、擴充、修改、修復非本公司授權或認可之零件所致之毀壞。
 - 產品標籤資訊不符或破損不清楚而無法確定產品序號時。

2.2 維修保固

本公司對於產品維修後，針對維修部份提供**六個月**保固期，在此期間內若同一零組件再發生相同故障時，即可享有免費維修服務。

2.3 服務網絡

公司	地址	電話	傳真
臺北總公司 (臺灣)	23678 新北市土城工業區自強街 16 號	+886 2-2269-6789	+886 2-2268-6682
台中營業處 (臺灣)		+886 4-2337-0825	+886 4-2337-0836
高雄營業處 (臺灣)		+886 7-333-6968	+886 7-536-8758
上海凡宜科技電子 有限公司(中國)	201109 上海市閔行區顧橋鎮都會路451號	+86 021-64907260	+86 021-6490-7276
Aplus FineTek Sensor Inc. (美國子公司)	355 S. Lemon Ave, Suite D, Walnut, CA 91789	1 909 598 2488	1 909 598 3188
Finetek Pte Ltd. (新加坡分公司)	37 Kaki Bukit Place, Level 4 Singapore 416215	+65 6452-6340	+65 6734-1878
FineTeK GmbH (德國分公司)	Bei den Kämpen 26 21220 Seevetal-Ramelsloh, Germany	+49 (0) 4185 8083 0	+49 (0) 4185 8083 80
PT. FineTek Automation Indonesia (印尼分公司)	PERGUDANGAN TUNAS BITUNG JL. Raya Serang KM. 13,8, Blok C3 No. 12&15, Bitung Cikupa, Tangerang 15710	+62 021-2958-1688	

3. 產品檢查

3.1 物品核對

- 流量計1組
- 操作說明書1份
- 產品檢驗單1份
- 接地環1組(2片)(選購)

3.2 安全查驗

- 拆封前請檢查外包裝有無變形或破損，並拍照存證作為事後補償依據
- 拆封後請檢查內容物有無變形或破損及一切品質問題，並拍照存證作為事後補據
- 開箱後請立即核對內容物是否與訂購內容相符，數量是否正確
- 若有以上異常狀況請於貨到7日內連絡本公司(連同照片)，否則恕不無償給予補換貨或維修

4. 概述

本公司電磁流量計，採用穩定性高的線圈激磁方式，其穩定性較傳統的生磁方式高。產品經過嚴苛的震動和抗雜訊測試後都能很穩定的工作，對於工業現場環境的複雜性有良好的耐受度，在實際的應用中有著更長的產品壽命。

電磁流量計從開始發展到今天，持續不斷的被改良，常被廣泛的應用到各類的工業流體管道的監控中，其中包含發電、水處理、食品、醫藥、船舶、染整、半導體製程等不勝枚舉。

由於電磁流量計的原理單純，適用範圍廣，只要適當的選型並與流體性質配合便能良好的應用在各類的環境之中。

5. 產品特點

- 測量時不受液體密度、粘度、溫度、壓力及導電率等變化而影響測量結果
- 測量管內只有兩個量測點，沒有阻流件及活動件，故不會造成壓力損失及堵塞的情況
- 可測試導電液體及含微量固體顆粒之流體流量
- 安裝時所需的直管段僅需流量計上游前 5D 及下游 2D，不需複雜的管路設計
- 測量的量程比可 1:100，尤其在小流量測量時精度高
- 具備自我診斷功能，可自我偵測激磁訊號、測量管是否為空管、電極是否污損
- 內襯可為一般型的 NBR(Nitrile)或氯丁橡膠,高溫以及酸鹼型的 PTFE(Teflon)
- 最高允許流體溫度可達 120°C (Teflon)
- 流量轉換器設定簡單、功能性強
- 支援參數修改紀錄、開關機紀錄(選購)
- 選單支援權限管理(選購)

6. 適用範圍

- 導電率： > 5 μ S/cm
- 流體性質：液體、含少量固體顆粒之液體。
- 應用產業：發電、水處理、食品、醫藥、船舶、染整、半導體製程


7. 環境條件

- 環境溫度: -40°C ~ 70°C
- 相對濕度: 5% ~ 95% of RH,無凝結水
- 大氣壓力: 86 ~ 106 KPa
- 電源: 100~240Vac 50/60Hz 或 DC24V

8. 工作原理

電磁流量計動作原理是基於法拉第電磁感應定律。當導體在磁場內運動，在與磁場方向、運動方向相互垂直方向的導體兩端，會有感應電動勢產生。電動勢的大小與導體運動速度和磁感應強度大小成正比。

在<圖一>中，當導電流體以平均流速 V (m/s)，通過裝有一對測量電極的一根內徑為 D (m) 的絕緣管子流動時，並且該管子處於一個均勻的磁感應強度為 B (T) 的磁場中。那麼，在這對電極上就會感應出垂直於磁場和流動方向的電動勢 (E)。由電磁感應定律， E 可寫作 (1) 式：



<圖一>

$$E = kB \cdot D \cdot V \text{ (V)} \dots\dots\dots (1)$$

式中 k 是比例係數。

體積流量可以寫作

$$q_v = \frac{\pi D^2}{4} V \text{ (m}^3/\text{s)} \dots\dots\dots (2)$$

由公式 (1) 和 (2) 可得到：

$$q_v = \frac{\pi D}{4k} \frac{E}{B} \text{ (m}^3/\text{s)} \dots\dots\dots (3)$$

因此電動勢可表示為：

$$E = \frac{4kB}{\pi D} q_v \text{ (V)} \dots\dots\dots (4)$$

當 B 是個常數時，公式 (3) 中

$$\frac{\pi D}{4k} \frac{1}{B} = A$$

，公式 (3) 改寫為：

$$q_v = AE \text{ (m}^3/\text{s)} \dots\dots\dots (5)$$

可見，流量 q_v 與電動勢 E 成正比。

9. 技術性能

9.1 基本參數和性能指標

9.1.1 產品技術規格表


項目	EPD34
螢幕	LCM 128*64 畫素背光型
按鍵	3 鍵式操作
通訊介面	RS-485 (Modbus)
精確度	±0.5% of reading@1m/s(0.2% optional)
介質溫度	合成橡膠：耐溫<80℃，主要應用於低濃度酸鹼液體，由於耐磨佳，可測量含雜質液體，適用於煤漿、泥漿、工業污水。 氯丁橡膠：耐溫<80℃，耐一般低濃度的酸、鹼腐蝕，適用於工業污水、自來水等。 PTFE：耐溫<120℃，化學性能穩定，主要應用於強酸強鹼液體或有清潔度要求的環境，適用於食品製程各類液體、化學藥液等。
環境溫度	-40 ~ 70℃*
流體導電度	>5 uS/cm
量測範圍	0.1m/s ~ 10m/s
電流輸出精度	0.1% of Pulse Output Accuracy, 溫度係數(100ppm/℃) **
耐壓	16Kg/cm ² (16Kg/cm ² 以上,請洽業務)
電流輸出模式	主動
類比輸出	4 ~ 20mA
電流輸出最大負載	< 700Ω
警報電流	3.6mA 或 22 mA
頻率輸出範圍	2 ~ 8 KHz
Pulse 寬度	自動 (脈波寬度 50%)
Pulse 模式	隔離式 NPN 晶體輸出 32Vdc/200mA
時間常數	1~100 s
控制輸出(DO)	隔離式 NPN 晶體輸出 32Vdc/200mA; 2-CH
控制輸入(DI)	乾接點 ON< 200Ω ; 1,000Ω< OFF; 1-CH
資料紀錄(選購)	500 筆資料,含萬年曆(內建電池壽命 6 個月)
鮑率	1200 ~ 57600 bps
防護等級	IP68(感測器), IP67/NEMA4X(傳送器)
接線盒材質	鋁合金
輸入電源	AC 100~240V 或 DC24V
消耗功率	< 10W
入線口規格	1/2"NPT*2 (感測器), M20x1.5x4 Female(傳送器)
分離型傳送器纜線長	< 100m***
激磁模式	Pulse DC
震動規範	MIL-STD-202G-201A:2002
EMC 規範	IEC/EN 61326-1 Class A table2

*LCM 低於-20℃時無法顯示

** 必須搭配 FineTek 感測器

*** 訊號電纜長度超過 50 米,空管檢測功能無法正常使用

9.1.2 精度等級與允許誤差



9.1.3 各管徑建議流量範圍

管徑 (mm)	流量範圍 (m ³ / h)	
	流速 0.1~1.0m/s	流速 1.0~10m/s
15	0.06~0.64	0.64~6.4
25	0.17~1.77	1.77~17.7
40	0.45~4.5	4.5~45.2
50	0.71~7.1	7.1~71
65	1.19~11.9	11.9~119
80	1.81~18.1	18.1~181
100	2.83~28.3	28.3~283
125	4.42~44.2	44.2~442
150	6.36~63.6	63.6~636
200	11.3~113	113~1130
250	17.7~177	177~1770
300	25.4~254	254~2540
350	34.6~346	346~3460
400	45.2~452	452~4520
450	57.2~572	572~5720
500	70.7~707	707~7070

9.1.4 各管徑耐壓及內徑規格

公稱通徑		量測管規格	量測管內徑			
			NBR		PTFE	
mm	Inch	JIS	mm	Inch	mm	Inch
25	1	20K	-	-	-	-
32	1-1/4	20K	-	-	-	-
40	1-1/2	20K	-	-	38	1.50
50	2	10K	-	-	49	1.93
65	2-1/2	10K	-	-	64	2.52
80	3	10K	-	-	77	3.03
100	4	10K	-	-	102	4.02
125	5	10K	-	-	128	5.04
150	6	10K	-	-	151	5.94
200	8	10K	-	-	207	8.15
250	10	10K	-	-	256	10.08
300	12	10K	-	-	301	11.85
350	14	10K	-	-	-	-
400	16	10K	-	-	-	-
450	18	10K	-	-	-	-
500	20	10K	-	-	-	-

9.1.5 內襯材料

	主要性能	適應範圍
丁晴橡膠 (NBR)	1. 有極好的彈性，高度扯斷力，耐磨性能好。 2. 耐一般低濃度酸、鹼、鹽溶液；不耐氧化性介質的腐蝕。	1. <80℃。 2. 中性強磨損的礦漿，煤漿和泥漿。
氯丁橡膠 (Neoprene)	1. 耐磨性中等。 2. 耐一般低濃度酸、鹼、鹽腐蝕。	1. <80℃。 2. 自來水、工業用水、海水。
PTFE	1. 化學性能穩定，能耐各種酸、鹼、鹽溶液和各種有機溶劑。不耐三氟化氯(ClF ₃)，高溫三氟化氧，高流速液氧，臭氧的腐蝕。	1. -20~120℃ 2. 濃酸、鹼等強腐蝕性介質。

	2. 耐磨性能一般。	
--	------------	--

9.1.6 電極材料

電極材料	耐蝕性能
不鏽鋼(316L)	用於水、污水或無機、有機腐蝕性介質。
哈氏合金	能耐氧化性酸：如硝酸、混酸或硫酸的混合介質的腐蝕；也耐氧化的鹽類：如 Fe^{2+} 、 Cu^{2+} 下；或含其他氧化劑的腐蝕：如高於常溫的次氯酸鹽溶液、海水的腐蝕。
鈦	能耐海水、各種氧化物和次氯酸鹽、氧化性酸(包括發煙硝酸)、有機酸鹼等的腐蝕；不耐較純的還原性酸(如硫酸、鹽酸)的腐蝕；但如酸中含有氧化劑時，耐腐蝕性大為降低。
鈮	具有優良的耐腐蝕性，和玻璃很相似。除了氫氟酸、發煙酸、鹼外，幾乎能耐一切化學介質（包括沸點的鹽酸、硝酸和 175°C 以下的硫酸）腐蝕。在鹼中不耐腐。

9.1.7 外殼防護等級


感測器：IP68

傳送器：IP67

9.2 執行標準

IEC 60068-2-3	EN 61326-1:2013
IEC 61326-1	EN 55011:2009/A:2010
IEC 60092-504	ISO 4064-1
JIS B2220	JIS B7554-1997
ANSI B16.5	DIN 25 Series

10. 外型尺寸



10.1 JIS 7.5K &10K & 20K


接續規格		JIS 10K															
公稱通徑(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
內襯材質		PTFE															
長度	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
外徑	φD	95	125	140	155	175	185	210	250	280	330	400	445	490	560	620	675
PCD	φC	70	90	105	120	140	150	175	210	240	290	355	400	445	510	565	620
法蘭厚度	t	12	14	16	16	18	18	18	20	22	22	24	24	26	28	30	30
螺絲孔傾斜角	θ°	45	45	45	45	45	22.5	22.5	22.5	22.5	15	15	11.25	11.25	11.25	9	9
螺絲孔直徑	θh	15	19	19	19	19	19	19	23	23	23	25	25	25	27	27	27
螺絲孔數量	N	4	4	4	4	4	8	8	8	8	12	12	16	16	16	20	20
傳感器高度	H1	75	88	125	125	145	145	195	195	270	305	365	406	470	530	580	630
總高度*1	H2	229	250	276	284	304	309	346	366	429	468	534	578	637	699	752	802
重量(Kg) *2	-	3.4	5.3	5.3	6.1	7.4	8.3	11.4	16	22	31.7	52.5	68	86.8	107.7	---	---

接續規格		JIS 20K											
公稱通徑(mm)		15	25	40	50	65	80	100	125	150	200	250	300
內襯材質		PTFE											
長度	L	200	200	200	200	200	200	250	250	300	350	400	500
外徑	φD	95	125	140	155	175	200	225	270	305	350	430	480
PCD	φC	70	90	105	120	140	160	185	225	260	305	380	430
法蘭厚度	t	14	16	18	18	20	22	24	26	28	30	34	36
螺絲孔傾斜角	θ°	45	45	45	22.5	22.5	22.5	22.5	22.5	15	15	15	11.25
螺絲孔直徑	θh	15	19	19	19	23	23	23	25	25	25	27	27
螺絲孔數量	N	4	4	4	8	8	8	8	8	12	12	12	16
傳感器高度	H1	75	88	125	125	145	145	195	195	270	305	365	406
總高度*1	H2	229	250	276	284	304	316	354	376	440	476	547	594
重量(Kg) *2	-	3.8	5.5	5.5	6.2	7.4	10.7	14.9	22	29.5	41.8	72.7	92.6

註：

*1: DN15~DN80、DN350~DN500 內襯保護(接地)環厚度 2mm 流量計總長度=L+4mm，DN100~DN300 內襯保護(接地)環厚度 0.5mm 流量計總長度=L+1mm。尺寸公差；流量計總長度±3mm，總高度±5mm

*2: 僅表示感測器重量，未包含傳送器重量 2.06kg




接續規格		JIS 7.5K										
公稱通徑(mm)		50	80	100	150	200	250	300	350	400	450	500
內襯材質		PTFE										
長度	L	200	200	250	300	350	400	500	500	600	600	600
外徑	ϕD	185	211	238	290	342	410	464	530	582	582	706
PCD	ϕC	143	168	195	247	299	360	414	472	524	585	639
法蘭厚度	t	16	18	18	20	21	23	26	26	26	28	28
螺絲孔傾斜角	θ°	45	45	45	30	22.5	22.5	18	18	15	15	15
螺絲孔直徑	θh	19	19	19	19	19	23	23	24	24	28	28
螺絲孔數量	N	4	4	4	6	8	8	10	10	12	12	12
傳感器高度	H1	125	145	195	270	305	365	406	470	530	580	630
總高度*1	H2	299	322	360	433	473	538	587	655	709	767	817
重量(Kg) *2	-	7.7	10.9	14.3	24.1	35.3	54.1	73.4	---	---	---	---

註：

*1: DN15~DN80、DN350~DN500 內襯保護(接地)環厚度 2mm 流量計總長度=L+4mm，DN100~DN300 內襯保護(接地)環厚度 0.5mm 流量計總長度=L+1mm。尺寸公差；流量計總長度 ± 3 mm，總高度 ± 5 mm

*2: 表示感測器重量，未包含傳送器重量 2.06kg



10.2 ANSI 150Lbs & 300Lbs


接續規格		ANSI 150Lbs															
公稱通徑(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
內襯材質		PTFE															
長度	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
外徑	ϕD	89	108	127	152	178	190	229	254	279	343	406	483	533	597	635	699
PCD	ϕC	60	79	98	121	140	152	191	216	241	298	362	432	476	540	578	635
法蘭厚度	t	10	13	16	17	21	22	22	22	24	27	29	30	33	35	38	41
螺絲孔傾斜角	θ°	45	45	45	45	45	45	22.5	22.5	22.5	22.5	15	15	15	11.25	11.25	9
螺絲孔直徑	θh	16	16	16	19	19	19	19	22	22	22	25	25	29	29	32	32
螺絲孔數量	N	4	4	4	4	4	4	8	8	8	8	12	12	12	16	16	20
傳感器高度	H1	76	89	125	125	145	145	195	195	265	305	365	406	470	530	580	630
總高度*1	H2	227	242	270	282	305	311	356	368	426	473	537	595	657	716	759	851
重量(Kg) *2	-	4.6	6.1	4.9	6.8	9.2	10.7	16.3	19.4	25.5	42.6	65.7	98	123.2	151.3	---	---

接續規格		ANSI 300Lbs															
公稱通徑(mm)		15	25	40	50	65	80	100	125	150	200	250	300	350	400	450	500
內襯材質		PTFE															
長度	L	200	200	200	200	200	200	250	250	300	350	400	500	500	600	600	600
外徑	ϕD	98	124	156	165	190	210	254	279	318	381	445	521	584	648	711	775
PCD	ϕC	67	89	114	127	149	168	200	235	270	330	387	451	514	572	629	686
法蘭厚度	t	13	16	19	21	24	27	30	33	35	40	46	49	52	56	59	62
螺絲孔傾斜角	θ°	45	45	45	22.5	22.5	22.5	22.5	22.5	15	15	11.25	11.25	9	9	7.5	7.5
螺絲孔直徑	θh	16	19	22	19	22	22	22	22	22	25	29	32	32	35	35	35
螺絲孔數量	N	4	4	4	8	8	8	8	8	12	12	16	16	20	20	24	24
傳感器高度	H1	76	89	125	125	145	145	195	195	265	305	365	406	470	530	580	630
總高度*1	H2	231	250	284	289	311	321	368	381	443	490	553	612	680	740	794	886
重量(Kg) *2	-	5.1	7.3	9.1	10.3	12.8	16.5	26.6	33	42.3	67.6	98.9	145	---	---	---	---

註：

*1: DN15~DN80、DN350~DN500 內襯保護(接地)環厚度 2mm 流量計總長度=L+4mm，DN100~DN300 內襯保護(接地)環厚度 0.5mm 流量計總長度=L+1mm。尺寸公差：流量計總長度±3mm，總高度±5mm


*2:僅表示感測器重量，未包含傳送器重量 2.06kg



10.3 DIN PN40 & PN16 & PN10

接續規格		DIN PN40						DIN PN16					
公稱通徑(mm)		15	25	40	50	65	80	65	80	100	125	150	200
內襯材質		PTFE						PTFE					
長度	L	200	200	200	200	200	200	200	200	250	250	300	350
外徑	ψD	95	115	150	165	185	200	185	200	220	250	285	340
PCD	ψC	65	85	110	125	145	160	145	160	180	210	240	295
法蘭厚度	t	18	18	18	20	22	24	18	20	20	22	22	24
螺絲孔傾斜角	θ°	45	45	45	45	22.5	22.5	45	22.5	22.5	22.5	22.5	15.0
螺絲孔直徑	θh	14	14	18	18	18	18	18	18	18	18	22	22
螺絲孔數量	N	4	4	4	4	8	8	4	8	8	8	8	12
傳感器高度	H1	76	89	125	125	145	145	145	145	195	195	265	305
總高度*1	H2	230	246	381	289	309	316	309	316	351	366	435	476
重量(Kg) *2	-	5.2	7.1	5.5	6.2	7.4	10.7	7	10.1	14.1	19.4	26.7	38.4

接續規格		DIN PN10						
公稱通徑(mm)		200	250	300	350	400	450	500
內襯材質		PTFE						
長度	L	350	400	500	500	600	600	600
外徑	ψD	340	395	445	490	565	615	670
PCD	ψC	295	350	400	460	515	565	620
法蘭厚度	t	24	26	26	28	32	38	38
螺絲孔傾斜角	θ°	22.5	15	15	11.25	11.25	9	9
螺絲孔直徑	θh	22	22	22	22	26	26	26
螺絲孔數量	N	8	12	12	16	16	20	20
傳感器高度	H1	305	365	406	470	530	580	630
總高度*1	H2	476	534	603	637	701	750	800
重量(Kg) *2	-	31.7	52.5	68	86.8	107.7	---	---



註：

*1: DN15~DN80、DN350~DN500 內襯保護(接地)環厚度 2mm 流量計總長度=L+4mm，DN100~DN300 內襯保護(接地)環厚度 0.5mm 流量計總長度=L+1mm。尺寸公差：流量計總長度±3mm，總高度±5mm

*2: 僅表示感測器重量，未包含傳送器重量 2.06kg

11. 安裝

流量計的設計、試驗和供電均有相關規定，用戶必須嚴格遵守說明，以確保流量計的安全操作及正常運作。

11.1 保證電磁流量計測量精度的必要條件

- 被測液體必須具有導電性
- 被測液體必須能充滿管道
- 被測液體必須均勻，以保證避免電導率的不均勻性（會產生嚴重干擾），如需動態加入化學物質，應在流量計下游處加入
- 電磁流量計系統必須良好接地，尤其在塑膠管道中一定要加裝接地環並實值接地
- 流量計入口直管段至少 5 倍 D(測量管道內徑)，出口直管段至少 2 倍 D
- 在流量計附近應避免強電磁場干擾；避免安裝在大型電機或變壓器等設備附近

11.2 安全措施

為保障人身和設備的安全，須遵守以下事項：


- 在選擇位置和安裝流量計之前，必須認真閱讀完本說明書有關部分，同時要考慮流量計、相關設備和機身環境的安全要求
- 應由具備一定流量計知識的人員進行流量計的安裝和維修
- 正確安裝流量計感測器及配管，保證密封安全可靠，液體壓力不得超過流量計規格上所能承受的最高工作壓力
- 採取適當措施，防止觸電事故
- 流量計的吊裝設備應符合安全規定

11.3 安裝前的檢查

- 檢查法蘭、內襯、外殼和出線套有無損傷
- 打開盒蓋、檢查接線印刷電路板有無鬆動或損壞
- 檢查銘牌中型號編碼與訂貨編碼是否相符

11.4 吊裝

流量計應採用正確吊裝方法進行吊裝，吊裝設備的安全載荷及防護措施應符合有關規定。禁止在傳送器箱體（一體式流量計）或接線盒（分離型流量計）處用繩拴起吊流量計。




11.5 正確安裝

正確地選擇安裝點和正確安裝流量計都是非常重要的環節，若在安裝環節失誤，輕者影響測量精度，重者會影響流量計的使用壽命，甚至會損壞流量計。


選擇安裝位置時需特別注意

a. 測量電極的軸線必須近似於水平方向（與水平線夾角一般為 10° 以內）。



b. 測量管道內必須完全充滿液體。


c. 流量計的前方最少要有 $5 \times D$ （ D 為流量計內徑）長度的直管段，後方最少要有 $2 \times D$ （ D 為流量計內徑）長度的直管段。



d. 流體的流動方向和流量計的箭頭方向一致。

e. 請避免在管道內出現真空現象，會損壞流量計的內襯。






- f. 在流量計附近應無強電磁場，流量計安裝場所的磁場強度應小於 400A/m（避免安裝在大型電機或變壓器等設備附近）。
- g. 在流量計附近應有充裕的空間，以便安裝和維護。
- h. 若測量管道有振動，在流量計的兩邊應有固定的支座。
- i. 測量不同介質的混合液時，混合點與流量計之間的距離最少要有 $30 \times D$ （ D 為流量計內徑長度）。



- j. 為方便今後流量計的清洗和維護，應安裝旁通管道。
安裝 PTFE 內襯的流量計時，連接兩法蘭的螺栓應注意均勻擰緊，否則容易壓壞 PTFE 內襯，盡可能使用扭力扳手。
- k. 流量計應避免強烈振動和過大的溫度變化，同時要防止腐蝕性液體的對流量計造成損害。
- l. 如果安裝地點易受陽光曝曬，應增加遮陽設施。
- m. 安裝感測器時，應盡可能的使測量管與製程管道位於同一個軸線上。
對 DN50 及以下公稱通徑的感測器，其軸線偏離不超過 2mm。DN65~DN150 其軸線偏離不超過 3mm， $\geq$ DN200 其軸線偏離不超過 4mm。
- n. 法蘭之間加裝的墊片，應有良好的耐腐蝕性能，該墊圈不得伸入管道內部，阻礙流體流動。
- o. 緊固流量計螺栓、螺母，其螺紋應完整無損，潤滑良好。應依據法蘭尺寸、力矩大小採用力矩扳手緊固螺栓。
- p. 在感測器鄰近管道進行焊接或火焰切割時，要採用隔離措施，防止襯裏受熱，且必須確認流量計未通電運行，防止損壞流量計。





11.6 管道上安裝注意事項

流量計安裝時，必須遵守以下安裝示意圖例，以確保流量計可以保證液體永遠充滿管道：(以下圖例僅為典型說明，並未包含全部可行的安裝方式，使用者應依實際工況進行安裝位置判斷。)

序號	圖例	說明
1		■ 應安裝在水平管道較低處和垂直向上處。 ■ 避免安裝在管道的最高點和垂直向下處。
2		■ 應安裝在管道的上升處。
3		■ 若管道落差超過 5m，在傳感器的下游安裝排氣閥 ■ 傳感器的下游應有一定的背壓。
4		■ 應在傳感器的下游安裝控制閥和切斷閥，而不應安裝在傳感器上游。
5		■ 傳感器絕對不能安裝在幫浦的進口處，安裝在幫浦的出口處。

11.7 接地要求

電磁流量計的接地是非常重要的，若接地不良，無法正常工作，感測器和傳送器部分應有良好的單獨接地線（銅芯截面積為 1.6mm^2 ），接地電阻 $<10\Omega$ 。

	圖例	說明
接地環		■ 若與感測器連接的管道是絕緣性的，則需用接地環 ■ 應選擇其材質和電極的材質一樣，避免被液體。 ■ 若被測介質是磨損性的，應選擇帶頸接地環。
接地方式		■ 流量計在金屬管道上的安裝，金屬管道內壁沒有絕緣塗層。
		■ 流量計在塑膠或內壁有絕緣塗料、油漆、內襯等管道上安裝時，應在傳感器的兩端安裝接地環。
		■ 流量計在陰極保護管道上安裝，防護電解腐蝕的管道一般在其壁和外壁是絕緣的，安裝時需注意接地環和管道上的法蘭應絕緣。


12. 接線與使用

12.1 訊號接線

12.1.1 接線注意事項


- 電源線建議選用二芯絕緣橡皮電纜線，線材外徑應大於 10mm。
- 當為交流供電時，L1 應接“火線”
- 所有的端子台接線應夾一字端子，並作好絕緣；應避免電線直接伸入端子台。
- 電流輸出端子出線電纜總阻抗不得大於規格所標稱的阻抗。
- 脈波或頻率輸出一般為 NPN 晶體輸出，需外接電源。
- 電纜出線頭應在在配線完成後鎖固，確保防水性能。

12.1.2 傳感器接線端子說明圖示




12.1.3 傳送器接線端子說明圖示

AC100~240V



			
勵磁訊號電纜線		訊號量測電纜線	
端子名稱	說明	端子名稱	說明
F1	勵磁訊號線	E1	感測訊號線
F2	勵磁訊號線	ES1	E1 感測訊號屏蔽線
S	勵磁訊號屏蔽線	E2	感測訊號線
		ES2	E2 感測訊號屏蔽線
		S	感測訊號屏蔽線
		E3	保留碼
		NC	保留碼
輸出入訊號端子用途說明			
端子名稱	說明	端子名稱	說明
L	電源輸入 L	D+	RS-485 通訊+
N	電源輸入 N	D-	RS-485 通訊-
PE	電源保護 GND	DO1+	警報 NPN 輸出 1+
		DO1-	警報 NPN 輸出 1-
DI+	數位輸入乾接點+	DO2+	警報 NPN 輸出 2+
DI-	數位輸入乾接點-	DO2-	警報 NPN 輸出 2-
MA+	4-20mA 電流輸出+	AI+	4-20mA 電流輸入+
MA-	4-20mA 電流輸出-	AI-	4-20mA 電流輸入-
P+	Pulse 脈波輸出+		
P-	Pulse 脈波輸出-		

DC24V



勵磁訊號電纜線		訊號量測電纜線	
端子名稱	說明	端子名稱	說明
F1	勵磁訊號線	E1	感測訊號線
F2	勵磁訊號線	ES1	E1 感測訊號屏蔽線
S	勵磁訊號屏蔽線	E2	感測訊號線
		ES2	E2 感測訊號屏蔽線
		S	感測訊號屏蔽線
		E3	保留碼
		NC	保留碼
輸出入訊號端子用途說明			
端子名稱	說明	端子名稱	說明
-	電源輸入 V -	D+	RS-485 通訊+
+	電源輸入 V +	D-	RS-485 通訊-
PE	電源保護 GND	DO1+	警報 NPN 輸出 1+
		DO1-	警報 NPN 輸出 1-
DI+	數位輸入乾接點+	DO2+	警報 NPN 輸出 2+
DI-	數位輸入乾接點-	DO2-	警報 NPN 輸出 2-
MA+	4-20mA 電流輸出+	AI+	4-20mA 電流輸入+
MA-	4-20mA 電流輸出-	AI-	4-20mA 電流輸入-
P+	Pulse 脈波輸出+		
P-	Pulse 脈波輸出-		


12.1.4 訊號電纜線接線說明

勵磁訊號線				
 單位：mm				
線皮顏色定義				
F1:紅色	F2:藍色	S:裸銅線		
Note1:歐式端子規格：F1,F2,S 採用Ø1.0mm				
Note2: 注意 Shield 線不可與其它線路短路。(建議以熱縮套管保護。)				
感測訊號線				
 單位：mm				
線皮顏色定義				
E1:紅色	ES1: 裸銅線	E2:藍色	ES2: 裸銅線	S:裸銅線
Note1:歐式端子規格：E1,E2,S 的採用Ø1.0mm；ES1,ES2 採用Ø1.7mm				
Note2:注意 Shield 線不可與其它線路短路。(建議以熱縮套管保護。)				

12.2 輸出入功能接線說明

12.2.1 4-20mA Current output

4~20mA Output



規格：


輸出模式：主動

最大負載阻抗：700 Ω

最大輸出電流：24mA

12.2.2 Pulse Output

Pulse Output



規格：

輸出模式：被動

最大輸入電壓：32 VDC

最大輸入電壓：200mA (保護)


最大工作頻率：< 8000 Hz

最小脈波寬度：0.0625 ms

脈波寬度控制：Auto 50% duty

12.2.3 RS-485 Communication

RS-485 Communication




規格：

終端電阻：120Ω

最大可連接的終端數量：256 (在線路阻抗匹配的情況下)

12.2.4 Digital output 1 (DO1)

Digital Output1(DO1)



規格：


輸出模式：被動

最大輸入電壓：32 VDC

最大輸入電流：200mA (保護)

12.2.5 Digital output 2 (DO2)

Digital Output2(DO2)



規格：


輸出模式：被動

最大輸入電壓：32 VDC

最大輸入電流：200mA (保護)

12.2.6 Digital input (DI)

Digital Input(DI)



規格：

輸入模式：乾接點(Dry-Contact)


驅動電壓：5 VDC

迴路最大電流：5 mA

最大輸入接點阻抗： $< 200\Omega$

12.2.7 Analogy input (AI)

Analogy Input(AI)



規格：

最大允許輸入電流：24mA


輸入阻抗：100Ω

13. 送電前的檢查


1. 流量計在運輸和安裝中有無損傷
2. 使用電源電壓同銘牌電壓是否相符
3. 使用正確流量值的保險絲
4. 流量計正確接地
5. 打開管道閥門使液體充滿管線系統，應注意排除洩露和系統內的殘留氣體
6. 接通流量計電源，通電預熱 10 分鐘即可正常工作

14. 參數功能說明

14.1 設定選單流程說明



14.1.1 顯示介面功能



14.1.2 參數設定狀態時的鍵功能：

			參數設定頁面		
按鍵	量測主畫面	選單模式	Read Only	數字編輯模式	清單編輯模式
ENT	進入選單	進入次選單		確認鍵(長按)	確認鍵(長按)
←		回上層	回上層	"左"位移鍵	回上層
↑		次選單項目【下】		數字："加"鍵	選項：下翻頁
ENT+ ←				取消	

14.2 各參數設定功能說明

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
快速設定(0)	裝置位號 (1.1)	N/A	此區參數是從標準選單中取出之捷徑			
	流量零點調整 (2.1)	N/A				
	流率滿量程 (1.5)	N/A				
	瞬時流率單位 (1.4)	N/A				
	低流量屏避 (2.4)	N/A				
	輸入訊號平均時間 (3.1)	N/A				
	脈波單位設定 (3.3)	N/A				
	總量重置設定 (1.9)					

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
基礎設定(1)	裝置位號 (1.1)	N/A	none	00001	00001~65535	客戶端工廠管理用 tag number
	量測液體類型 (1.2)	N/A	-	水	水(Water)	設定量測液體類型種類
	流量計口徑 (1.3)	10~100 mm(1.3.1)	mm	actual	10,15,25,32,40,50,65,80,100	設定流量計公稱通徑， 可計算流量量程
		125~500 mm(1.3.2)			125,150,200,250,300,350,400,450,500	
	瞬時流率單位 (1.4)	N/A	-	m³/h	L/(s,min,h), m³/(s,min,h), gal/(s,min,h), kg(s,min,h), Ton(s,min,h) (若選重量單位，流量自動和密度相乘) "L/s","L/m","L/h","m³/s", "m³/m","m³/h","gal/s", "gal/m","gal/h","kg/s","kg/m","kg/h", "Ton/s","Ton/m", "Ton/h","m³/d"	瞬時流量自動以此設定單位顯示
	流率滿量程 (1.5)	N/A	=流率單位	(5m/s) x (口徑 mm/2)² x pi x 流率單位	(0.1 ~ 10.0m/s) x (口徑 mm/2)² x pi x 流率單位 (000.00)	此量程設定直接對應到 4-20mA 輸出及頻率輸出值
	流體方向 (1.6)	N/A	dir	順向 (Forward)	順向,逆向	可選擇流體的流動方向
	總量累積單位 (1.7)	N/A	-	Liter	Liter,gal,m³,kg,Ton	總量流量自動以此設定單位顯示
	總量累積模式 (1.8)	N/A	none	順向	順向,逆向,雙向	Σ+正向流測量,Σ-反向流測量,ΣΔ雙向流測量 (Δ= 正流 - 反流)
	總量重置設定 (1.9)	N/A	none	Cancel	否,是	將目前顯示的總累積量清除。

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
進階設定 (2)	流量零點調整 (2.1)	AUTO	m/s	Actual	-0.5000~+0.5000	在滿管無流量時的零點 流量補償
		MANUAL				
	流量系數 K (2.2)	N/A	none	1.000	0.000~3.000	流量傳感器特徵參數， 真實值 = 測量值 x k
	密度 (2.3)	N/A	g/cm³	1.0000	0.0001~9.9999	質量流量=體積流量*密度
	低流量屏避 (2.4)	N/A	%	0.5	0.00~100.00	當管路內有微流或振動 時，找低流顯示屏避 (判斷流率大於該值才顯 示並累積)
	順向總量起始值 (2.5)	N/A	=總量累積單位	0	0~9999999999	初始化目前的正向累積 總量
	反向總量起始值 (2.6)	N/A	=總量累積單位	0	0~9999999999	初始化目前的反向累積 總量

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
輸出入訊號 設定(3)	輸入訊號平均時間 (3.1)	N/A	second(s)	3	0~100	將實際流量做平均值輸出
	脈波輸出模式 (3.2)	N/A	none	Pulse NO	Pulse NO, Pulse NC, Frequency	Pulse 輸出接點的初始狀態，或用頻率來表示流率(如果選頻率,依流率表示),Pulse No,Nc 為總量輸出的高低電位狀態
	脈波單位設定 (3.3)	N/A	Unit/pulse	0.1 L	0.001~100(L,gal, m³,g,kg,Ton) L/pulse,gal/pulse,m³/pulse,g/ pulse,kg/pulse,Ton/pulse	可設定每個 pulse 所代表的流量
	頻率設定 (3.4)	N/A	Hz,kHz	2K	1~8K (00.000)	在設定的流率滿量程下的最高輸出頻率值
	電流輸出模式設定 (3.5)	N/A	none	4-20	4-20,0-20	選擇電流輸出模式
	電流輸出 4mA 微調 (3.6)	N/A	count	0	-5000~5000	可調整 4mA 輸出的基準值
	電流輸出 20mA 微調 (3.7)	N/A	count	0	-5000~5000	可調整 20mA 輸出的基準值
	輸入 1 接點功能 (3.8)	N/A	N/A	None	None,總量重置	輸入接點動作時所執行的功能。
	輸入 1 接點型式 (3.9)	N/A	N/A	NO	NO,NC	設定輸入接點的原始狀態，可能 NO 或 NC
	濾波視窗變化率 (3.10)	N/A	m/s	1	00.000~10.000	降低流量突波變化準位設定
	濾波視窗權重 (3.11)	N/A	%	10	0~100	降低流量突波變化
	中位數波視窗 (3.12)	N/A	%	Enable	Dusable,Enable	降低流量測量時雜訊的影響

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
警報設定(4)	流率上限 (4.1)	N/A	瞬時流率 單位	該口徑最大值	0~±至流率上限值(000.00)-	設定流率超過此設定時，則被觸發報警
	流率下限 (4.2)	N/A	瞬時流率 單位	該口徑最小值	0~±至流率上限值(000.00)-	設定流率低於此設定時，則被觸發報警
	空管檢測 (4.3)	N/A	N/A	Enable	Disable, Enable	當電導率低到某一程度即判斷為空管狀態
	輸出 1 功能 (4.4)	N/A	N/A	流量上限警報	None,流量上限警報,流量下限警報,空管警報,系統異常	選擇輸出 1 接點的功能
	輸出 1 接點 型式(4.5)	N/A	N/A	NO	NO,NC	設定警報接點的原始狀態，可能 NO 或 NC
	輸出 2 功能 (4.6)	N/A	N/A	流量下限警報	None,流量上限警報,流量下限警報,空管警報,系統異常	選擇輸出 2 接點的功能
	輸出 2 接點 型式(4.7)	N/A	N/A	NO	NO,NC	設定警報接點的原始狀態，可能 NO 或 NC
	警報電流功能 (4.8)	N/A	N/A	None	None,空管警報,系統異常	選擇電流警報的功能
	警報電流設定 (4.9)	N/A	mA	3.6	3.6,3.8,20.5,22	設定當警報發生時之輸出電流值
	溫度警報 (4.10)	N/A	N/A	1	0: 關, 1:開	設定當溫度過高時,觸發警報

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
系統設定 (5)	系統語言 (5.1)	N/A	N/A	English	English, 繁中, 簡中	系統顯示語言
	系統資訊 (5.2)	測量管狀態	N/A	Actual	正常/空管	檢測目前量測管內液體是否溢過兩電極測量點
		目前流速	m/s	Actual	N/A	測量目前流體速度的真實值
		液體阻抗	kΩ	Actual	N/A	測量目前流體電阻值真實值
		系統狀態碼	N/A	Actual	0000 0000 ~ FFFF FFFF	顯示目前系統狀態代碼
	自我測試 (5.3)	N/A	N/A	取消	正常, 電路異常(Device 周邊溝通與確認), 激磁異常, 環境溫度過高, 電極汙損 警示訊息無中文	正常: 系統自我檢測無發現任何異常現象 電路異常: 板溫過高/過低、I/O 失效、無法檢知訊號 激磁異常: 激磁電流無法檢知或電流異常 環境過高: 環境溫度超出可允許範圍 電極汙損: 電極嚴重被覆蓋非導電性物質
	類比輸入 設定(5.4)	4mA 顯示值	N/A	0000	0~9999	設定輸入電流的對應顯示值 Scale Low
		20mA 顯示值	N/A	100	0~9999	設定輸入電流的對應顯示值 Scale High
		4-20mA 輸入 單位	N/A	Kpa	None, Kpa, Mpa, Psi, Bar, °C, °F	輸入電流對應顯示單位設定
		小數點位數	N/A	1	0~3	設定小數點位數

Modbus 通訊 (5.5)	Modbus ID(2.13.1)	N/A	1	1~255	基本通訊設定
	BaudRate (2.13.2)	BPS	9600	1200,2400,4800,9600,19200, 38400,57600	
	Data bit(2.13.3)	N/A	8	8,9	
	Parity (2.13.4)	N/A	none	none,odd,even	
	Stop bit(2.13.5)	N/A	1	1,2	
恢復出廠設 定值 (5.6)	N/A	N/A	取消	取消,確認(Cancel, Accept)	
市電頻率 (5.7)	N/A	Hz	50	50,60	選擇接入之市電頻率
LCM 亮度 (5.8)	N/A	N/A	32	15~40	選擇顯示對比亮度
選單密碼 (5.9)	使用者密碼 (5.9.1)	N/A	00000	0~99999	使用者密碼
	管理者密碼 (5.9.2)				管理者密碼

主選項	次選項	說明	單位	出廠值	設定值範圍	功能描述
訊號模擬 (6) (離開此選單 後回到正常 模式)	流速模擬 (6.1)	N/A	m/s	0	-10 ~ 10	模擬流速，使系統做出相應的反應。(選單無返回計時)
	流量模擬 (6.2)	N/A	流量單位	0	0~該口徑最大值	模擬流量，使系統做出相應的反應。(選單無返回計時)
	電流輸出模擬 (6.3)	N/A	mA	4mA	3.6~22	僅電流輸出 port 做出反應。(選單無返回計時)
	頻率輸出模擬 (6.4)	N/A	Hz(pulse/秒)	2	2~8000	pulse port 做出相應頻率輸出。(選單無返回計時)
	輸出接點 1 狀態 (6.5)	N/A	N/A	OFF	ON/OFF	測試接點是否正常。(選單無返回計時)
	輸出接點 2 狀態 (6.6)	N/A	N/A	OFF	ON/OFF	測試接點是否正常。(選單無返回計時)
	輸入訊號 1 狀態 (6.7)	N/A	N/A	Actual	ON/OFF	測試接點是否正常。(選單無返回計時)
	電流輸入狀態 (6.8)	N/A	N/A	Actual	0~24mA	顯示目前輸入電流值。(選單無返回計時)
系統紀錄 (7)	日期設定 (7.1)	N/A	N/A	actual	年：17~99, 月：01~12, 日：01~31	設定日期
	時間設定 (7.2)	N/A	N/A	actual	時：00~23, 分：00~59, 秒：00~59	設定時間
	系統清除 (7.3)	N/A	N/A	取消	取消，確認	清除全部紀錄
	系統紀錄資訊 (7.4)	N/A	N/A	actual	N/A	檢視記錄資訊
產品資訊 (8)	韌體版本 (8.1)			actual		

※選項 1.3、1.9、2.2、2.5、2.6、5.6、5.9、7.3, 只有管理者權限可作更改

14.3 系統紀錄說明

顯示畫面說明

② ③ ④ System Log 7.4 2021/07/09 18:19:54 Device Tag No. Data : 2 User 0067/0067 ⑤ ⑥	
⑦ ④ System Log 7.4 2021/07/09 18:11:52 Power on System 0066/0066	
項次	欄位說明
1	事件發生日期。
2	被修改參數名稱，修改者為『User』、『Admin』
3	被修改參數內容
4	修改參數的操作者，區分為『User』、『Admin』、『System』
5	事件發生時間
6	目前總紀錄筆數
7	系統事件發生名稱，修改者為『System』，詳見下表。

分類	訊息	說明
系統硬體狀態	系統開機	系統開機時紀錄當下時間
	系統關機	系統關機時紀錄當下時間
使用者設定	總量重置設定	允許操作者為 Admin
	流量係數 K	允許操作者為 Admin
	流量計口徑	允許操作者為 Admin
	管理者密碼	允許操作者為 Admin
	使用者密碼	允許操作者為 User/Admin
	恢復出廠設定值	允許操作者為 Admin
	其它操作介面參數	權限分級詳見參數設定功能說明 14.2

15. 產品選型

型號	訂購料號
EPD30	EPD10000-A
EPD34	EPD10400-A

EPD1 ^{⑤⑥} ^{⑩⑪⑫} ^{⑬⑭⑮} ^{⑯⑰} ^{⑱⑲} ^{⑳㉑} ^{㉓㉔㉕㉖㉗㉘} A ^{㉙㉚㉛㉜㉝㉞㉟}

⑤⑥ 型號
 00: 標準型 04: 分離型

⑩⑪⑫ 口徑
 015: 15mm 100: 100mm 350: 350mm
 025: 25mm 125: 125mm 400: 400mm
 040: 40mm 150: 150mm 450: 450mm
 050: 50mm 200: 200mm 500: 500mm
 065: 65mm 250: 250mm
 080: 80mm 300: 300mm

⑬⑭⑮ 接續種類
 C48: ANSI B16.5 Class 150
 C49: ANSI B16.5 Class 300
 A41: JIS B2220 7.5K
 A42: JIS B2220 10K
 A45: JIS B2220 20K
 D57: DIN 2501 PN10
 D58: DIN 2501 PN16
 D60: DIN 2501 PN40

⑯⑰ 接續材質
 MD: 碳鋼
 MA: SUS304
 MC: SUS316L

⑱⑲ 內襯材質 (15、25口徑只能選PTFE)
 08: 氯丁橡膠
 21: PTFE(精度0.2%、0.3%僅能選用PTFE材質)
 37: 丁晴橡膠

(接續下頁)

EPD1 ⁰⁵ ⁰⁶ 0 0 -A ¹⁰ ¹¹ ¹² ¹³ ¹⁴ ¹⁵ ¹⁶ ¹⁷ ¹⁸ ¹⁹ ²⁰ ²¹ A ²³ ²⁴ ²⁵ ²⁶ ²⁷ ²⁸

②① 電極材質

MC: SUS316L
MF: 鈦
MK: 鈮
MJ: 哈氏合金(C-276)

②③ 電源

A: 100~240Vac, 50/60Hz
D: 24Vdc
N: 100~240Vac, 50/60Hz (含資料記錄功能)
R: 24Vdc (含資料記錄功能)

②④ 精度

F: 0.5%
G: 0.3%
H: 0.2%

②⑤ 接地環材質

00: 無接地環
MA: SUS304
MC: SUS316L
MF: 鈦
MK: 鈮
MJ: 哈氏合金(C-276)

②⑦ 訊號電纜線長度

(標準型因無電纜線,故此碼選"00:無須選擇"即可)

00: 無需選擇(僅標準型)
10: 10米(標準長度)
15: 15米
20: 20米
:
:
:
95: 95米
A0: 100米

16. 運輸與貯存

為防止流量計在轉運時受到損傷，在到達安裝現場以前，請保持製造廠發運時的包裝狀態。在貯存過程中，貯存地點應具備下列條件：

- 需做適當防雨及防潮
- 盡可能的減少運送時的振動並避免撞擊
- 溫度範圍-20~70℃
- 溼度低於 80%
- 貯存使用過的感測器，須先清除附著於襯裏和電極表面上的被測介質，避免長期暴露在空氣中而氧化
- 露天貯存，流量計性能可能會受影響

17. 故障檢查與維修

如果流量計出現故障與無法達到精度要求，請嘗試利用下表說明進行排除

現象	檢查	處理方法
無法達到精度	■ 流量計零點是否漂移	■ 進行零點校正。請參閱選單，要做到飽管且水不流動方可執行。
	■ 管道是否充滿液體	■ 改變安裝位置，使流體充滿管道
	■ 流量計是否在接近流率範圍上限或下限值工作	■ 降低或提高流速，使流速介於 1m/s ~10m/s 之間
	■ 檢查量程設定是否正確	■ 確保流量計量程和接收流量計訊號設備設定義的量程是一致的
	■ 檢查流量計輸出連接是否正確	■ 重新連接，並確保線路通暢
	■ 流量計與管路之間接地是否良好	■ 將流量計正確接地，接地阻接不得高於 10Ω
	■ 檢查傳送器的感測器 K 系數值與感測器銘牌上標示是否一致	■ K 系數值可能被第三人調整過，請調回
開機無畫面	■ 檢查流量計電源、開關、保險絲等供電設施是否正常	■ 排除異常，使流量計可以正確取得電源 ■ 流量計可能損壞，聯繫原廠銷售。
無法進行通訊	■ 檢查 RS-485 通訊功能	■ 確認 RS-485 轉換器是否能正常工作。 ■ 各項 RS-485 位元格式/ID/鮑率參數查核正確
無脈波輸出	■ 檢查是否有額外供電 12VDC 給輸出端	■ 出廠值為無源 NPN 輸出，需外接電源
顯示值亂跳不穩定	■ 管道液體導電率不高	■ 檢查比對管道液體材料特性
	■ 接地環未附帶或是連接不良	■ 檢查訂單明細，無論管道材質都須有接地環；針對接地接線請詳細閱讀操作說明書使用方法
	■ 流量計安裝於馬達高壓干擾區域	■ 訊號線或電源請重新拉線遠離干擾區域
	■ 空管水氣潮濕干擾	■ 開啟空管警報
	■ 流量計電源火線對地有漏電壓流	■ 重新拉電源線，流量計重置回原廠值，依流量計管道尺寸與 K 值等等參數重新設定
	■ 轉換器或主機電路板故障	■ 備品電路板更新或與原廠聯繫處理

管道有流量但顯示沒有流量值	■ 低流量屏蔽值是否大於現在流量	■ 修正並降低數值(參考出廠值)
	■ 分離型流量計的信號線與勵磁線是否正常	■ 查看傳感器與傳送器兩邊端子台線路正確與鎖緊
	■ 流量計感測器箭頭方向與管道水流一致嗎	■ 檢查感測器方向正確並且在參數流體方向亦要正確
	■ 管道流體是否是否有充滿測量管	■ 感測器最好安裝在水平管路下凹處或管後有爬升段確保飽管
螢幕顯示異常訊息	■ 查詢操作手冊異常訊息顯示	■ 詳見異常訊息顯示說明，適當排查。
流量計本體內襯凸起	■ 管道是否因負壓產生	■ 負壓的問題能否移除，不行的話，須改用其他產品。
4-20mA 輸出不正常	■ 無電流輸出	■ 移除原有線路，使用手持電錶檢測，確認產品功能 ■ 恢復出廠預設值後重新測試。 ■ 聯繫當地技術人員進行異常排除。
流量誤差大	■ 濾波設定參數是否錯誤	■ 減少訊號平均時間並關閉中位數濾波功能。
	■ 內襯與電極是否覆蓋附著物	■ 檢查或清潔電極覆蓋的附著物。
	■ 排除上述兩點問題	■ 聯繫當地技術人員進行異常排除。

錯誤代碼說明

警示狀態	說明
Empty Tube	量測管內沒有液體或液體導電度低於 5us/cm
Sensor Discon.	傳感器未正確連接或勵磁電流異常，無法正常檢知流量。
Electrode Coating	電極嚴重被覆蓋非導電性物質。
Init. Comm. Err.	內部功能異常。(請嘗試重開機)

18. MODBUS 通訊協定(參照英文版)